



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Gingerbread Nursery School & Kindergarten Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma
Lead in Schools and Child Care Program (LWSC) on 09/23/2026
from 602 VILLA DRIVE, Norman, OK 73071.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	1839-2	1	1	Giant house	CF		Faucet to the right of the sink	8.2 ppb	<1 ppb	9/23/26 7:00	Remediation Recommended	
2	1839-10	3	1	Kindergarden	WC		Sink to the left, water fountain on the right side	2.1 ppb	<1 ppb	9/23/26 7:00	Remediation Recommended	
3	1839-11	3	1	Kindergarden	CF		Sink to the Right	<1 ppb	<1 ppb	9/23/26 7:00	No Further Action	
4	1839-9	2	1	The elfs	CF		Sink to the Right	<1 ppb	<1 ppb	9/23/26 7:00	No Further Action	
5	1839-8	2	1	The elfs	CF		Sink to the Left	<1 ppb	<1 ppb	9/23/26 7:00	No Further Action	
6	1839-7	1	1	The Scotties	CF		Sink to the right	<1 ppb	<1 ppb	9/23/26 7:00	No Further Action	
7	1839-6	1	1	The Scotties	DW		Water fountain to the right of the sink	<1 ppb	<1 ppb	9/23/26 7:00	No Further Action	
8	1839-5	1	1	The Scotties	CF		Classroom Faucet to the left	<1 ppb	<1 ppb	9/23/26 7:00	No Further Action	
9	1839-4	1	1	SunRoom	DW		Water fountain to the right of the sink	<1 ppb	<1 ppb	9/23/26 7:00	No Further Action	
10	1839-3	1	1	SunRoom	CF		Faucet to the left of the sink	<1 ppb	<1 ppb	9/23/26 7:00	No Further Action	
11	1839-1	1	1	Giant house	DW		Water fountain to the right of the sink	<1 ppb	<1 ppb	9/23/26 7:00	No Further Action	