



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Avant Garde Preschool South Sheridan

Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma
Lead in Schools and Child Care Program (LWSC) on 07/17/2026
from 7607 S Sheridan Rd, Tulsa, OK 74133.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	3101-8	1	1	Toddlers	CF		Single faucet	1.55 ppb	1.72 ppb	07/17/2026 06:29	Remediation Recommended	
2	3101-2	1	1	Mobile infants	CF		2 compartment faucet	<1 ppb	<1 ppb	07/17/2026 06:29	No Further Action	
3	3101-1	1	1	2s	CF		Single faucet	<1 ppb	<1 ppb	07/17/2026 06:29	No Further Action	
4	3101-3	1	1	Preschool	CF		Left faucet	<1 ppb	<1 ppb	07/17/2026 06:29	No Further Action	
5	3101-4	1	1	Preschool	CF		Right faucet	<1 ppb	<1 ppb	07/17/2026 06:29	No Further Action	
6	3101-5	1	1	PreK	CF		Single faucet	<1 ppb	<1 ppb	07/17/2026 06:29	No Further Action	
7	3101-7	1	1	Kitchen	KF		3 compartment faucet	<1 ppb	<1 ppb	07/17/2026 06:29	No Further Action	