



OKLAHOMA DRINKING WATER

LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

Middle Earth Learning Center Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 09/23/2026 from 201 Triad Village Drive, Norman, OK 73071.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	3122-14	1	1	Infants-Dreamers 2	CF		Sink to the right	2.4 ppb	<1 ppb	9/23/26 6:00	Remediation Recommended	
2	3122-13	1	1	Infants-Dreamers 2	CF		Sink to the left	2.2 ppb	<1 ppb	9/23/26 6:00	Remediation Recommended	
3	3122-11	1	1	1 year olds - Adventures	CF		Sink to the left	1.5 ppb	<1 ppb	9/23/26 6:00	Remediation Recommended	
4	3122-12	1	1	1 year olds - Adventures	CF		Sink to the right	1.4 ppb	<1 ppb	9/23/26 6:00	Remediation Recommended	
5	3122-7	1	1	3 years old - Re-K1	CF			1.1 ppb	<1 ppb	9/23/26 6:00	Remediation Recommended	
6	3122-9	1	1	Little Gym	CF			1.1 ppb	<1 ppb	9/23/26 6:00	Remediation Recommended	
7	3122-10	1	1	1 year olds - Rangers	CF			<1 ppb	<1 ppb	9/23/26 6:00	No Further Action	
8	3122-15	1	1	Infants-Dreamers 1	CF		Sink to the left	<1 ppb	<1 ppb	9/23/26 6:00	No Further Action	
9	3122-17	1	1	Hallway entrance	WC	Elkay	Water fountain to the right	<1 ppb	<1 ppb	9/23/26 6:00	No Further Action	
10	3122-16	1	1	Infants-Dreamers 1	CF		Sink to the right	<1 ppb	<1 ppb	9/23/26 6:00	No Further Action	
11	3122-1	1	1	Kitchen	KF			<1 ppb	<1 ppb	9/23/26 6:00	No Further Action	
12	3122-2	1	1	Kitchen	IM		IM to the left	<1 ppb		9/23/26 6:00	No Further Action	
13	3122-3	1	1	Infants - Dreamers 3	CF			<1 ppb	<1 ppb	9/23/26 6:00	No Further Action	
14	3122-4	1	1	4-5 years old	CF			<1 ppb	<1 ppb	9/23/26 6:00	No Further Action	
15	3122-5	1	1	2 years old	CF			<1 ppb	<1 ppb	9/23/26 6:00	No Further Action	
16	3122-6	1	1	1 year old	CF			<1 ppb	<1 ppb	9/23/26 6:00	No Further Action	
17	3122-8	1	1	3 years old - Explorers	CF			<1 ppb	<1 ppb	9/23/26 6:00	No Further Action	

[illegible]