



OKLAHOMA DRINKING WATER

# LEAD TESTING

IN PUBLIC SCHOOLS & CHILD CARE FACILITIES

## Oak Grove Head Start Initial Sampling Results

Samples outlined in this report were collected under the Oklahoma Lead in Schools and Child Care Program (LWSC) on 05/07/2026 from 3301 Sw 17Th St, Oklahoma City, OK 73108.

See below for an overview of the outlet descriptions noted in the results report:

Outlet Type Code Key:

CF: Classroom Faucet

KF: Kitchen Faucet

BF: Bathroom Faucet

NS: Nurse Office Sink

RA: Refrigerator Appliance

OF: Outdoor Faucet

IM: Ice Machine

DW: Drinking Water Fountain

WC: Water Cooler With Chiller Unit

Water Cooler Definition: A machine that is connected to the building's water supply for a continuous supply of water and to electricity to run a refrigeration unit to cool the incoming water.

Drinking Fountain Definition: A machine that is connected to the building's water supply for a continuous supply of water.

#	Outlet ID	Building #	Floor #	Room # / Name	Outlet Type Code	Water Cooler Make and Model	Comments	Initial First Draw Result Final (ppb)	Initial Flush Draw Result Final (ppb)	Initial Sample Date(s)	Action Needed?	Remediation Action Taken
1	5325-2	1	1	Kitchen	KF		2 compartment faucet in kitchen prep room	2.14 ppb	<1 ppb	05/07/2026 06:20	Remediation Recommended	
2	5325-1	1	1	Cafeteria	WC	EZFS8_1H	Single water cooler in cafeteria, outside kitchen door to left	<1 ppb	<1 ppb	05/07/2026 06:20	No Further Action	
3	5325-3	1	1	Entrance hallway	WC	EZFS8_1H	In main entrance hallway, left of door, across from offices	<1 ppb	<1 ppb	05/07/2026 06:20	No Further Action	
4	5325-4	1	1	Room B	BF		First bathroom on left wall, closest to door	<1 ppb	<1 ppb	05/07/2026 06:20	No Further Action	
5	5325-5	1	1	Room B	BF		Second bathroom on left wall, farthest from door	<1 ppb	<1 ppb	05/07/2026 06:20	No Further Action	
6	5325-6	1	1	Room C	BF		Second bathroom on right wall, farthest from door	<1 ppb	<1 ppb	05/07/2026 06:30	No Further Action	
7	5325-7	1	1	Room C	BF		First bathroom on right wall, closest to door	<1 ppb	<1 ppb	05/07/2026 06:30	No Further Action	

