



Oklahoma State Fire Marshal
P.O. Box 36690
Oklahoma City, Oklahoma 73136-2690
(405) 522-5005 | www.oklahoma.gov/fire

FIRE SPRINKLER PLAN SUBMITTAL INSTRUCTIONS

Submitting Plans

Plans and documents are to be submitted into the Oklahoma State Fire Marshal Electronic Plan Review Portal ([Plan Reviews](#)). Paper plans sent to the State Fire Marshal will be rejected and sent back.

Only Oklahoma Licensed Fire Sprinkler Companies may submit fire sprinkler plans online and in the portal. The professional section of the application is required to be completed. The review process will not start until all documents and fees are received.

The quality of the submitted plans affects the quality of the plan review and the ability to shorten turnaround time. Refer to the Sprinkler Submittal Checklist to verify your plans meet these NFPA 13 requirements for working plans.

Applications

One (1) Fire Sprinkler Plan Review Submittal Online Application is to be used per building. Verify and provide the OKSFM building permit file number in the application if applicable to this submittal. Verify you have received a copy and or reviewed the copy of the building plan review comments if applicable. All sections of the fire sprinkler application shall be correct and completely filled out.

The applicant is responsible to ensure that design specifications and plans are complete and in compliance with the requirements of the current adopted International Fire Code, NFPA 13, NFPA 13R and NFPA 13D.

Review Timeframe

Once the all required information or documents are verified in the online system, an invoice will be sent from the online system indicating fees due. Once payment is received, the review process will begin.

Plans are reviewed on a first come, first served basis, and in the order received. While we strive for a 30-day turnaround, plan review times can be longer dependent on number of submittals and or staff available. Actual review time is dependent on the size and complexity of the project and the quality of the plans and or documents provided. The quality of the submitted plans affects the quality of the plan review and the ability to shorten turnaround time.

Resubmittals (Due to Denial or Disapproval)

Any information that is not provided will result in the plans being denied by the plan review secretaries. Any plans disapproved by the plan reviewers which will incur a full resubmittal application and incur all associated plan review fees.

After completed plans review

After an approval has been issued by the plan reviewer, the plans will be electronically stamped by the OKSFM. When the plan review is approved by OKSFM, you will be notified by email.

- Login to the OKSFM Accela online customer account.



Oklahoma State Fire Marshal
P.O. Box 36690
Oklahoma City, Oklahoma 73136-2690
(405) 522-5005 | www.oklahoma.gov/fire

- Retrieve approved documents. Print the Approved Plans/Documents in COLOR and to the size of plan sheet designed.
- Note: A printed copy of the approved plans and permit must be available on the job site at all times.

ALL APPROVED PLANS OR DOCUMENTS MUST BE PRINTED IN COLOR AND TO ACTUAL SIZE AND OR SCALE SUBMITTED. ANY PLANS ONSITE THAT ARE NOT IN COLOR WILL RESULT IN FAILED INSPECTIONS BY THE OKSFM AGENT AND INCUR ADDITIONAL FEES AND OR CAUSE DELAYS.

DOCUMENTS REQUIRED FOR EVERY SUBMITTAL:

- Fire Sprinkler Plan Review Application fully completed (Online Portal)
- Signed NFPA 13 Owner's Information Certificate
- Plans **verified** to meet the FS Working Plan Checklist
- Hydraulic Calculations in the form specified in the adopted edition of NFPA 13. Shown in the exact format indicated in NFPA
- Seismic Sway Bracing Calculations (Lateral and Longitudinal) if applicable
- Manufacturer's specification for each sprinkler type used and all other devices. "0 psi/friction loss" flex lines must be called out/shown on plans!
- Submittal brochure w/cover sheet & Material data sheets (**highlight** or **mark** for models/items used in system)
- Water Flow verified/approved by the water purveyor within last year

Fire Sprinkler Plan Review Submittal Requirements

The following is a list of requirements for all plan submittals. Any information that is not provided will result in the plans being rejected and returned without review.

Application

1. Completed Online Application Form with all fields filled in.

Site Plan

2. Site Plan showing the location of the entire buildings, water line, fire department connection, and fire hydrant(s).

Plans

3. Plans must be computer/CAD designed to a scale no smaller than 1/8". Room names shall be provided. Designed by a minimum of NICET III Certification or Professional Engineer with discipline in fire protection. Submitted by an Oklahoma Licensed Fire Sprinkler company.

Calculations

4. One (1) set of calculations

Specifications

5. One (1) set of specification book/books. Uploaded to system.
6. VERIFY all drawings, calculations, and specifications uploaded to system.