

**TITLE 165. CORPORATION COMMISSION
CHAPTER 26. ABOVEGROUND STORAGE TANKS**

Effective October 1, 2024

**Last Amended
The Oklahoma Register
Volume 41, Number 23
August 15, 2024 publication
Pages 1711-3126**

PLEASE NOTE: This is not the official version of the Oklahoma Administrative Code. Official rules are available from the Office of Administrative Rules of the Oklahoma Secretary of State. This copy is provided as a convenience to our customers. In the event this unofficial version of the rules differs from the official version of the Oklahoma Administrative Code in any way, the official version shall control.

TABLE OF CONTENTS**SUBCHAPTER 1. GENERAL PROVISIONS****Part 1. Purpose and Definitions**

165:26-1-1. Purpose

165:26-1-2. Definitions

Part 3. Scope of Rules

165:26-1-22. Exclusions

Part 4. Administrative Provisions

165:26-1-25.1. Citation of rules

165:26-1-26. Hearings, orders and exceptions

165:26-1-26.1 Public participation

165:26-1-28. Variances

165:26-1-30. Severability

Part 5. Standards and Codes

165:26-1-31. Codes and standards

165:26-1-33. Local jurisdiction

Part 6. Financial Responsibility

165:26-1-36. Financial responsibility

165:26-1-37. Evidence of financial responsibility

Part 7. Notification and Reporting Requirements

165:26-1-41. General reporting requirements

165:26-1-42. New tank systems

165:26-1-47. Transfer of ownership

165:26-1-48. Tank and line tightness testing

Part 9. Recordkeeping

165:26-1-55. Availability of records

165:26-1-56. Repair records

165:26-1-57. Tank installation, closure and removal records

165:26-1-58. Release detection and corrosion protection records

165:26-1-59. Spill and overflow records

165:26-1-60. Piping records

Part 11. Fees

165:26-1-70. Fees

Part 13. Shutdown of Operations

165:26-1-90. Shutdown of operations

Part 15. Licensing Procedures

165:26-1-110. Licensing procedure for AST Installers

165:26-1-110.1. Licensing procedure for AST Removers

165:26-1-110.2. Licensing procedure for Testers

165:26-1-111. Licensee disciplinary action procedure

165:26-1-113. License penalties

SUBCHAPTER 2. GENERAL REQUIREMENTS FOR ABOVEGROUND STORAGE TANK SYSTEMS**Part 1. Design and Installation**

- 165:26-2-1.1. Aboveground storage tank installation
- 165:26-2-1.3. Approved tanks, tank design
- 165:26-2-3. Aboveground storage tank spacing
- 165:26-2-4. Distance to be kept around tanks
 - Requirements on fill pipes
- 165:26-2-5.1. General spill and overfill prevention requirements
- 165:26-2-6. Vent piping requirements
- 165:26-2-7. Collision barriers
- 165:26-2-8. Installation testing

Part 3. Secondary Containment

- 165:26-2-31. Double-walled tanks
- 165:26-2-32. Secondary containment
- 165:26-2-32.1. Spill Prevention, Control and Countermeasure Plan

Part 4. Requirements for Corrosion Protection Systems

- 165:26-2-40. Corrosion protection
- 165:26-2-41. Compliance with corrosion protection requirements and manufacturer's specifications
- 165:26-2-42. Frequency and criteria of inspections and tests

Part 5. Piping

- 165:26-2-51. Piping protection
- 165:26-2-52. Piping and gravity flow
- 165:26-2-53. Valves on piping
- 165:26-2-54. Aboveground storage tank piping materials
- 165:26-2-55. Underground piping materials

Part 7. Vault Requirements

- 165:26-2-71. Vaults

Part 9. Dispenser Requirements

- 165:26-2-91. Dispensers
 - 165:26-2-91.1 Display on dispenser
- 165:26-2-92. Dispenser hose
- 165:26-2-93. Nozzles

Part 11. Tank Filling Procedures

- 165:26-2-111. Tank filling operation

Part 13. Miscellaneous Safety Provisions

- 165:26-2-131. Fencing
- 165:26-2-132. Required signs
- 165:26-2-133. Sources of ignition

Part 15. Electrical

- 165:26-2-151. Electrical requirements

Part 19. Repairs to Aboveground Storage Tank Systems

- 165:26-2-191. Repairs to aboveground tank systems

Part 21. Removal and Closure of Aboveground Storage Tank Systems

- 165:26-2-210. Tank removal and closure
- 165:26-2-211. Compliance with removal and closure requirements
- 165:26-2-212. Temporary removal from service
- 165:26-2-212.1 Requirements for returning to service
- 165:26-2-213. Permanent closure
- 165:26-2-214. Assessing the site at tank closure or change in service

SUBCHAPTER 3. RELEASE PREVENTION AND DETECTION REQUIREMENTS

Part 4. Release Detection

- 165:26-3-19. General monitoring requirements
- 165:26-3-20. General release detection methods and devices
- 165:26-3-20.1. Monitoring requirements for aboveground tanks and aboveground piping
- 165:26-3-20.2. Installation and monitoring requirements for underground piping

Part 14. Release Reporting Requirements

- 165:26-3-77. Release reporting

Part 17. Release Investigation

- 165:26-3-171. Release investigation and confirmation

SUBCHAPTER 4. INSPECTIONS, NOTICES OF VIOLATION, FIELD CITATIONS AND FORMAL ENFORCEMENT ACTIONS

Part 1. Inspections

- 165:26-4-1. Owner/operator cooperation
- 165:26-4-2. Authority of the Commission
- 165:26-4-3. Completion of inspections
- 165:26-4-5. Inspection for compliance

Part 5. Notices of Violation, Field Citations, and Formal Enforcement Actions

- 165:26-4-15. Notices of Violation, Field Citations, and Formal Enforcement Actions
- 165:26-4-16. Notices of Violation
- 165:26-4-17. Re-inspection, Field Citation and Formal Enforcement Actions
- 165:26-4-18. Issuance of a Field Citation and payment of fine or hearing

Part 7. Penalties

- 165:26-4-21. Penalties

SUBCHAPTER 6. REQUIREMENTS FOR ABOVEGROUND STORAGE TANK SYSTEMS UTILIZED BY AIRPORTS OPEN TO THE PUBLIC

Part 1. General Application and Compliance Provisions

- 165:26-6-1. Application
- 165:26-6-2. Timeframes for registration and compliance with rules
- 165:26-6-3. Codes and standards

Part 3. Tank Design, Construction, Capacity and Location Requirements

- 165:26-6-10. Maximum capacity for tanks
- 165:26-6-14. Tank distance requirements

Part 9. Piping Requirements

165:26-6-40. Aboveground piping at airports

Part 15. Dispenser Requirements

165:26-6-61. Dispenser hose

165:26-6-63. Dispenser location at airports

165:26-6-64. Specific requirements for airport dispensers

Part 17. Tank Filling Procedures

165:26-6-73. Emergency controls

Part 19. Dispensing Procedures

165:26-6-80. Dispensing fuel into aircraft

165:26-6-81. Static protection and bonding

Part 21. Miscellaneous Safety Provisions

165:26-6-86. Required signs

165:26-6-88. Fire extinguishers

SUBCHAPTER 8. REQUIREMENTS FOR ABOVEGROUND STORAGE TANK SYSTEMS UTILIZED BY MARINAS

Part 1. General Application and Compliance Provisions

165:26-8-1. Application

165:26-8-2. Timeframes for registration and compliance with rules

165:26-8-2.1. Release detection requirements for marinas

Part 3. Tank Design, Construction, Capacity and Location Requirements

165:26-8-10. Maximum capacity for tanks

165:26-8-13. Location of aboveground storage tanks at marinas

Part 9. Over-Water Piping Requirements

165:26-8-40.1. Over-water piping at marinas

165:26-8-40.2. Installation requirements for over-water piping

Part 15. Dispenser Requirements

165:26-8-61. Dispenser hose

165:26-8-62. Nozzles

165:26-8-63. Dispenser location at marinas

165:26-8-64. Specific requirements for dispensers at marinas; maintenance

Part 19. Dispensing Procedures

165:26-8-80. Attendants at marinas

Part 21. Miscellaneous Safety Provisions

165:26-8-86. Required signs

165:26-8-88. Fire extinguishers

SUBCHAPTER 10. REQUIREMENTS FOR ABOVEGROUND STORAGE TANK SYSTEMS UTILIZED BY RETAIL FACILITIES

Part 1. General Application and Compliance Provisions

165:26-10-1. Application

165:26-10-2. Timeframes for registration and compliance with rules

Part 3. Tank Design, Construction, Capacity and Location Requirements

165:26-10-10. Maximum capacity for tanks

SUBCHAPTER 12. REQUIREMENTS FOR ABOVEGROUND STORAGE TANK SYSTEMS UTILIZED AT FLEET AND COMMERCIAL FACILITIES**Part 1. General Application and Compliance Provisions**

165:26-12-1. Application

165:26-12-2. Timeframes for registration and compliance with rules

Part 3. Tank Design, Construction, Capacity and Location Requirements

165:26-12-10. Maximum capacity for tanks

165:26-12-14. Tank distance requirements

SUBCHAPTER 14. REQUIREMENTS FOR ABOVEGROUND STORAGE TANK SYSTEMS UTILIZED BY BULK PLANT FACILITIES**Part 1. General Application and Compliance Provisions**

165:26-14-1. Application

165:26-14-2. Timeframes for registration and compliance with rules

Part 3. Tank Design, Construction, Capacity and Location Requirements

165:26-14-10. Maximum capacity for tanks

Part 15. Dispenser Requirements

165:26-14-60. Dispensers

165:26-14-63. Location of loading facilities

165:26-14-64. Specific requirements for loading facilities

Part 17. Tank Filling Procedures

165:26-14-70. Tank filling operation

165:26-14-71. Switch loading

Part 19. Dispensing Procedures

165:26-14-80. Dispensing fuel into tank vehicles

165:26-14-81. Static protection and bonding

Part 21. Miscellaneous Safety Provisions

165:26-14-86. Required signs

APPENDIX G. FINE CITATIONS TABLE**APPENDIX H. SPACING (SHELL TO SHELL) BETWEEN ADJACENT TANKS****APPENDIX I. TOTAL CAPACITY OF VENTING DEVICES****APPENDIX J. TABLE ESTABLISHING PERMEABILITY RATES FOR SECONDARY CONTAINMENT****[Authority:** OKLA. CONST. Art IX, §§ 18, 19; 17 O.S., §§ 301 et seq.; 27A O.S. § 1-3-101]**[Source:** Codified 7-13-93]

SUBCHAPTER 1. GENERAL PROVISIONS**PART 1. PURPOSE AND DEFINITIONS****165:26-1-1. Purpose**

The purpose of this Chapter is to provide a regulatory program for the safe operation of aboveground storage tanks in Oklahoma and to prevent and contain pollution caused by leaking aboveground storage tank systems and to reduce the hazards of fire and explosion. PSTD adopts NFPA 30 and 30A, which serves as a basis for the standards in this Chapter. A copy of NFPA 30 and 30A is available for inspection at PSTD during regular business hours.

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 17 Ok Reg 2875, eff 7-15-00; Amended at 34 Ok Reg 958, eff 9-11-17]

165:26-1-2. Definitions

In addition to the terms defined in 17 O.S. §§ 301 et seq., the following words or terms, when used in this Chapter, shall have the following meaning unless the context clearly indicates otherwise:

"Aboveground storage tank" or "AST" means a "Storage tank" as defined in 17 O.S. § 303(40) that has more than ninety percent (90%) of its volume above the surface of the ground.

"Aboveground storage tank system" means a closed-plumbed system including, but not limited to, the aboveground storage tank(s), the individual storage tank compartments, the lines, the dispenser for a given product, containment sump, if any, ancillary equipment or a delivery truck that is connected to the storage tank system.

"Agent" means a person authorized by another to act on their behalf, either out of employment or contract.

"Airports" mean landing facilities for aircraft which are routinely available for public use (whether routinely used or not). Airports as used in this Chapter do not include private airstrips or private airports.

"Ancillary equipment" means any device including, but not limited to: devices, such as piping, fittings, flanges, valves, and pumps that are used to distribute, meter, or control the flow of regulated substances to or from a petroleum storage tank.

"ATG" means automatic tank gauging.

"Backfill" is the material that is placed in piping excavation to support and separate the piping from the natural environment.

"BTEX" means benzene, toluene, ethylbenzene and xylene.

"Bulk plant" means petroleum storage tank facility where regulated substances are received by tank vessels, pipelines, tank cars, or tank vehicles and are stored or blended in mass quantities or bulk for the purpose of distributing them by a tank vessel, pipeline, tank car, tank vehicle, portable tank or other container, for wholesale or retail sale.

"Cathodic protection" means a technique designed to prevent the corrosion of a metal surface by making that surface the cathode of an electrochemical cell. For example, protection can be accomplished with an impressed current system or a galvanic anode system

"Change in service" means a change in the status of a storage tank (i.e., from currently in use to temporarily out of use); or change of regulated substance that a storage tank contains.

"Commission" or "OCC" means the Oklahoma Corporation Commission.

"Compatible" means the ability of two (2) or more substances to maintain their respective physical properties upon contact with one another for the design life of the PST system under conditions likely to be encountered in the system.

"Corrosion expert" means an individual having the requisite knowledge, experience, certification, and training to design and install corrosion protection systems.

"Emergency venting" means a construction method or device that relieves excessive internal pressure due to fire exposure.

"EPA" means the United States Environmental Protection Agency.

"Electronic signature" means an electronic signature as defined in OAC 165:5-1-3.

"Farm tank" is a tank located on a tract of land devoted to the production of crops or raising animals, including fish, and associated residences and improvements. A farm tank must be located on the farm property. "Farm" includes but is not limited to fish hatcheries, rangeland, and nurseries with growing operations.

"Fire protected tank" means an aboveground storage tank that is listed in accordance with UL 2085, *Standard for Insulated Aboveground Tanks for Flammable and Combustible Liquids*, or an equivalent test procedure that consists of a primary tank provided with protection from physical damage and fire-resistive protection from exposure to a high-intensity liquid pool fire.

"Fire resistant tank" means a UL listed aboveground storage tank that provides fire-resistant protection from exposures to a high intensity liquid pool fire.

"Fleet and Commercial" means any facility that uses aboveground storage tanks to store regulated substances for use in its own vehicles or equipment.

"Flow-through process tank" means a tank that forms an integral part of a production process through which there is a steady, variable, recurring or intermittent flow of material during the operation of the process. Flow-through process tanks do not include tanks used for the storage of materials prior to their introduction to the process or for the storage of finished products or by-products from the production process.

"Formal Enforcement Action" means the process of ensuring compliance with Commission regulations, rules, orders, requirements, standards, and/or state law when a violation occurs and PSTD initiates an enforcement Complaint under the contempt procedure in OAC 165:5 Subchapter 19 to be heard at the Commission by an Administrative Law Judge or the Commissioners.

"Impervious barrier" means a barrier of sufficient thickness, density, and composition that is impenetrable to the regulated substance, has a permeability of at least 1×10^{-6} cm/sec., and will prevent the discharge to the environment of any regulated substance for a period of at least as long as the maximum anticipated time during which the regulated substance will be in contact with the impervious material.

"Important building" means a building that is considered not expendable in an exposure fire.

"In service" means a petroleum storage tank that contains a regulated substance, and/or has a regulated substance added to or withdrawn from it.

"Licensed Environmental Consultant" means an individual who has a current license issued by PSTD to perform corrective action.

"Maintenance" means the normal operational upkeep necessary to prevent a petroleum storage tank system from releasing product.

"Marina" means any fuel storage tank system located on or by the water for the purpose of fueling watercraft.

"Mobile or Temporary Tank at Construction Site" means a fuel tank used for less than twelve (12) months at a construction site.

"OCC Licensed Tester" or "licensed tester" means an individual who has a current license

issued by PSTD to perform tank system testing.

"Operator" means any person in control of or having responsibility for the daily operation of the storage tank system, whether by lease, contract, or other form of agreement. The term "operator" also includes a past operator at the time of a release, tank closure, violation of the Oklahoma Petroleum Storage Tank Consolidation Act, or a rule promulgated thereunder, or a requirement of the Commission. In the case of a storage tank system in service/use before November 8, 1984, but no longer in service/use on that date, the last person to operate the storage tank system immediately before the discontinuation of its service/use.

"Owner" means any person as set forth in 17 O.S. § 303(27), including the real property owner where the storage tank system is still present, the storage tank system presence is a trade fixture or improvement or both. It is not necessary that the real property owner sold, used, or stored regulated substances in, of, or from the storage tank system. However, a real property owner who has a storage tank system located on their property that was taken out of service/use prior to November 8, 1984, is not considered to be a storage tank owner for any PSTD regulated purpose.

"Permanent out of use" or **"POU"** means a petroleum storage tank system that is not in service/use, does not contain regulated substances, and is not intended to be placed back in service/use.

"Pier" means dock, floating dock, and wharf.

"Positive sampling, testing, or monitoring results" means the results of sampling, testing or monitoring using any of the release detection methods described in this Chapter that indicate that a release from a petroleum storage tank system may have occurred.

"Private airport" means an airport used only by its owner and regulated as a fleet and commercial facility.

"Private airstrip" means a personal residential takeoff and landing facility attached to the airstrip owner's residential property and used only by the owner.

"PSTD" means Petroleum Storage Tank Division.

"Public Utility" means any entity providing gas, electricity, water, or telecommunication services for public use.

"Regulated substance" means antifreeze, motor oil, motor fuel, gasoline, kerosene, diesel or aviation fuel as set forth in 17 O.S. § 305. It does not include compressed natural gas, liquid natural gas or propane.

"Release detection" means the methodology used in determining whether a release of regulated substances has occurred from a petroleum storage tank system into the environment or into the interstitial area between the storage tank system and its secondary barrier.

"Residential tank" is a tank located on real property used primarily for dwelling purposes.

"Retail facility" means a service station, convenience store or any other facility selling a PSTD regulated substance that is open to the general public.

"Sacrificial anode" means a device to reduce or prevent corrosion of a metal in an electrolyte by galvanic coupling to a more anodic metal.

"Secondary containment" means a system installed around a petroleum storage tank or system that is designed to prevent a release from migrating beyond the secondary containment system outer wall (in the case of a double-walled tank system) or excavation area (in the case of a liner or vault system) before the release can be detected. Such a system may include, but is not limited to, impervious barriers (both natural and synthetic), double walls, or vaults.

"TPH" means total petroleum hydrocarbons.

"Tampering" means willful intention in an attempt to deceive, cheat or misrepresent facts to the public. Tampering also presents a risk to the environment as well as public health, safety, and welfare.

"Tank tightness testing" or **"precision testing"** means a procedure for testing a petroleum storage tank system's integrity.

"Temporary out of use" or **"TOU"** means the status of a petroleum storage tank system that has been taken out of service/use with the intent to permanently close or return to service.

"Total venting capacity" means the sum of the normal and emergency vent capacities and is determined by the wetted area of the tank as provided in Appendix I.

"Used Motor Oil" is any spent motor oil removed from a motor vehicle.

"Vault" means an enclosure consisting of four (4) walls, a floor, and a top for the purpose of containing a liquid storage tank and not intended to be occupied by personnel other than for inspection, repair, or maintenance of the vault, the storage tank or related equipment.

"Wetted area of cylindrical tank" means seventy-five percent (75%) of the total exposed area of the tank ends and shell.

"Wetted area of rectangular tank" means one hundred percent (100%) of the surface area of the bottom, sides, and ends of the tank.

"Wetted area of vertical tank" means the first thirty feet (30') above grade of the exposed shell and floor.

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 12 Ok Reg 2057, eff 7-1-95; Amended at 14 Ok Reg 2515, eff 7-1-97; Amended at 15 Ok Reg 3020, eff 7-15-98; Amended at 17 Ok Reg 2875, eff 7-15-00; Amended at 19 Ok Reg 1616, eff 6-13-02; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 26 Ok Reg 1831, eff 7-1-09; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 33 Ok Reg 615, eff 8-25-16; Amended at 34 Ok Reg 958, eff 9-11-17; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 36 Ok Reg 576, eff 8-1-19; Amended at 37 Ok Reg 1143, eff 10-1-20; Amended at 41 Ok Reg 1803, eff 10-1-24]

PART 3. SCOPE OF RULES

165:26-1-21. Overview of applicability [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 33 Ok Reg 615, eff 8-25-16; Amended at 36 Ok Reg 578, eff 8-1-19; Revoked at 39 Ok Reg 965, eff 10-1-22]

165:26-1-22. Exclusions

(a) The following classes of aboveground storage tanks or systems are specifically excluded from all provisions of this Chapter:

- (1) All tanks used in the exploration or production of oil and gas, including well service equipment and natural gas compression equipment.
- (2) All mobile or temporary tanks used at construction sites.
- (3) All farm and ranch tanks.
- (4) All tanks used by public utilities in the generation of electric power for public use.
- (5) All tanks used by manufacturers in the production of goods.

(6) Emergency generator tanks.

(7) All tanks that contain motor oil, used motor oil or antifreeze located at retail motor vehicle lubrication facilities or automotive service centers.

(8) Tanks used for storing heating oil for consumptive use on the premises where stored.

(b) These exclusions do not extend to permanently located fuel storage tanks used to fuel company vehicles, even though the vehicles may be driven to production or construction sites.

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 17 Ok Reg 2875, eff 7-15-00; Amended at 19 Ok Reg 1616, eff 6-13-02; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 31 Ok Reg 1010, eff 9-12-14; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 36 Ok Reg 579, eff 8-1-19; Amended at 37 Ok Reg 1143, eff 10-1-20]

165:26-1-23. Citation of rules [RENUMBERED TO 165:26-1-25.1]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 17 Ok Reg 2875, eff 7-15-00; Renumbered to 165:26-1-25.1 at 23 Ok Reg 2297, eff 7-1-06]

165:26-1-24. Other standards and regulations [RENUMBERED TO 165:26-1-32]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 17 Ok Reg 2875, eff 7-15-00; Renumbered to 165:26-1-32 at 23 Ok Reg 2297, eff 7-1-06]

165:26-1-25. Local jurisdiction [RENUMBERED TO 165:26-1-33]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00; Added at 21 Ok Reg 2079, eff 7-1-04; Renumbered to 165:26-1-33 at 23 Ok Reg 2297, eff 7-1-06]

PART 4. ADMINISTRATIVE PROVISIONS

165:26-1-25.1. Citation of rules

This Chapter will be known as the Oklahoma Corporation Commission's General Rules and Regulations Governing Aboveground Storage Tanks and are to be cited as Chapter 26 of Commission rules.

[Source: Renumbered from 165:26-1-23 at 23 Ok Reg 2297, eff 7-1-06; Amended at 32 Ok Reg 794, eff 8-27-15]

165:26-1-26. Hearings, orders and exceptions

(a) The Commission will issue orders after notice and hearing as necessary to enforce the provisions of this Chapter or PSTD enabling statutes to protect property, the public health and safety, and the environment.

(b) Hearings to enforce or exceptions to the provisions of this Chapter or PSTD enabling statutes will be conducted in accordance with OAC 165:5.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 37 Ok Reg 1143, eff 10-1-20]

165:26-1-26.1. Public participation

PSTD shall provide for public participation in the enforcement process by:

- (1) Providing notice and opportunity for public comment on all proposed settlements of civil enforcement actions (except where immediate action is necessary to adequately protect human health and the environment);
- (2) Investigating and providing responses to citizen complaints about violations;
- (3) Not opposing citizen intervention when permissive intervention is allowed by statute, rule or regulation.
- (4) PSTD hearings are open to the public and interested parties are encouraged to attend.

[Source: Added at 33 Ok Reg 615, eff 8-25-16; Amended at 35 Ok Reg 1010, eff 10-1-18]

165:26-1-27. Changes to rules [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 25 Ok Reg 2187, eff 7-11-08]

165:26-1-28. Variances

A variance to any provision of this Chapter may be granted by the Commission after application, notice and hearing and administrative review by staff. A variance is effective on the date of order issuance. Instructions on the variance process can be found at OAC 165:5-21-3.1.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 34 Ok Reg 958, eff 9-11-17; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 36 Ok Reg 579, eff 8-1-19]

165:26-1-29. Notices [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 23 Ok Reg 2297, eff 7-1-06; Revoked at 32 Ok Reg 794, eff 8-27-15]

165:26-1-30. Severability

If any part of this Chapter is ruled invalid, by a court of competent jurisdiction, the remainder of the Chapter will remain in full force and effect.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

165:26-1-30.2. Consultation of Petroleum Storage Tank Division [REVOKED]

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 25 Ok Reg 2187, eff 7-11-08; Revoked at 36 Ok Reg 579, eff 8-1-19]

165:26-1-30.3. Licensing procedure for aboveground storage tank licensee [RENUMBERED TO 165:26-1-110]

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended

at 23 Ok Reg 2297, eff 7-1-06; Renumbered to 165:26-1-110 at 25 Ok Reg 2187, eff 7-11-08]

165:26-1-30.4. Fees [RENUMBERED TO 165:26-1-70]

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Renumbered to 165:26-1-70 at 23 Ok Reg 2297, eff 7-1-06]

PART 5. STANDARDS AND CODES

165:26-1-31. Codes and standards

(a) Specific references to documents listed below are made throughout the Aboveground Storage Tank Rules. Each of these documents or parts thereof is adopted and incorporated by reference as a standard. In the event these rules are in conflict with any of the standards set forth below, the provisions of these rules shall prevail. New editions of codes and standards supersede all previous editions. These codes and standards will be updated periodically through a formal rulemaking procedure initiated by PSTD to reflect any substantive or relevant changes. A copy is available for inspection at the Offices of the Petroleum Storage Tank Division during regular business hours.

(1) American National Standards Institute (ANSI) Standards: American Society of Mechanical Engineers (ASME):

(A) ASME B31.3 2022, "Process Piping."

(B) ASME B31.4 2022, "Pipeline Transportation Systems for Liquids and Slurries."

(2) American Petroleum Institute (API) Standards:

(A) API Recommended Practice 652, "Linings of Aboveground Petroleum Storage Tank Bottoms," Fifth Edition, 2020.

(B) API Publication 1628 SET, "A Guide to the Assessment and Remediation of Underground Petroleum Releases." Third Edition, July 1996.

(C) API Standard 653, "Tank Inspection, Repair, Alteration, and Reconstruction," Fifth Edition, (2014), Addendum 1 (2018), Addendum 2 (2020).

(3) American Society for Testing and Materials (ASTM) Standards: ASTM E1739-95 (2015), "Standard Guide for Risk-Based Corrective Action Applied at Petroleum Release Sites."

(4) National Association of Corrosion Engineers (NACE) Standards: NACE SP0169-2013, "Control of External Corrosion on Underground or Submerged Metallic Piping Systems."

(5) National Fire Protection Association (NFPA) Standards:

(A) Standard Number 30, 2024, "Flammable and Combustible Liquids Code."

(B) Standard Number 30A, 2024, "Motor Fuel Dispensing Facilities and Repair Garages."

(6) Underwriter's Laboratory (UL) Standards:

(A) Standard UL142, 2021, "Steel Aboveground Tanks for Flammable and Combustible Liquids."

(B) Standard UL842, 2020, "Valves for Flammable Fluids."

(C) Standard UL971, 2021, "Nonmetallic Underground Piping for Flammable Liquids."

(7) Petroleum Equipment Institute:

(A) RP 200-19, "Installation of Aboveground Storage Systems" (2019 Edition).

(B) RP 1000-22, "Marina Fueling Systems" (2022 Edition).

(C) RP 1300-20, "Design, Installation, Service, Repair and Maintenance of Aviation Fueling Systems" (2020 Edition).

(D) RP 1700-18, "Recommended Practices for the Closure of Underground Storage Tank and Shop-Fabricated Aboveground Storage Tank Systems" (2018 Edition).

- (8) "Spill Prevention, Control and Countermeasure Regulation," 40 CFR 112.
- (b) The standards set forth in (a) of this Section are also available from the following sources:
- (1) American National Standards Institute (ANSI), Thirteenth Floor; 11 West 42nd Street, New York City, New York, 10036; Telephone: (212) 642-4900.
 - (2) American Society of Mechanical Engineers (ASME), Three Park Ave., 23S2, New York, NY 10016-5990; Telephone (800) 843-2763.
 - (3) American Petroleum Institute (API), Publications and Distribution, 1220 "L" Street, N.W., Washington, D.C. 20005-4070; Telephone (202) 682-8000.
 - (4) American Society for Testing and Materials (ASTM), 100 Bar Harbor Drive, West Conshohocken, Pennsylvania 19428-2959; Telephone (610) 832-9585.
 - (5) National Association of Corrosion Engineers (NACE), 1440 South Creek Drive, Houston, Texas 77084; Telephone (281) 492-0535.
 - (6) National Fire Protection Association (NFPA), 1 Batterymarch Park, Quincy, Massachusetts 02269-9101; Telephone (800) 344-3555.
 - (7) National Groundwater Association (NGWA), 601 Dempsey Road, Westerville, Ohio 43081; Telephone (614) 898-7791.
 - (8) Underwriter's Laboratory (UL), 333 Pfingsten Road, Northbrook, Illinois 60062; Telephone (847) 272-8800, extension 2612.
 - (9) Petroleum Equipment Institute, P.O. Box 2380, Tulsa, Oklahoma, 74101-2380; Telephone (918) 494-9696.
 - (10) Association of Materials Protection and Performance (AMPP/NACE), 15835 Park Ten Place, Houston, Texas 77084. Telephone (800) 797-6223.

[Source: Added at 9 Ok Reg 3739, eff 8-27-92; Amended at 12 Ok Reg 2057, eff 7-1-95; Amended at 14 Ok Reg 2515, eff 7-1-97; Amended at 15 Ok Reg 3020, eff 7-15-98; Amended at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 23 Ok Reg 144, eff 10-6-05 (emergency); Amended at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 26 Ok Reg 1831, eff 7-1-09; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 33 Ok Reg 615, eff 8-25-16; Amended at 34 Ok Reg 958, eff 9-11-17; Amended at 36 Ok Reg 579, eff 8-1-19; Amended at 39 Ok Reg 966, eff 10-1-22; Amended at 40 Ok Reg 1797, eff 10-1-23; Amended at 41 Ok Reg 1803, eff 10-1-24]

165:26-1-32. Other standards and regulations [REVOKED]

[Source: Renumbered from 165:26-1-24 at 23 Ok Reg 2297, eff 7-1-06; Revoked at 25 Ok Reg 2187, eff 7-11-08]

165:26-1-33. Local jurisdiction

Local jurisdictions, including but not limited to municipalities or rural fire districts, are allowed to adopt their own codes regarding aboveground storage tanks as long as they do not conflict with and are at least as stringent as the state's rules. Some local jurisdictions may prohibit aboveground storage tanks through zoning and/or ordinances.

[Source: Renumbered from 165:26-1-25 at 23 Ok Reg 2297, eff 7-1-06]

PART 6. FINANCIAL RESPONSIBILITY

165:26-1-36. Financial responsibility

- (a) This Subchapter applies to owners and operators of all petroleum aboveground storage tank (AST) systems except as otherwise provided in this Section.
- (b) Federal government entities whose debts and liabilities are the debts and liabilities of the United States are exempt from the requirements of this Subchapter.
- (c) The requirements of this Subchapter do not apply to owners and operators of any AST system described in 165:26-1-22, "Exclusions."
- (d) If the owner and operator of a petroleum aboveground storage tank are separate persons, only one person is required to demonstrate financial responsibility; however, both parties are liable in the event of noncompliance.
- (e) An owner or operator may satisfy the requirements of this Subchapter by use of the Oklahoma Petroleum Storage Tank Indemnity Fund (ref: Okla. Stat. Title 17 § 327.3). There is a co-pay for use of this mechanism. Compliance may also be satisfied by use of any of the mechanisms listed in 165:26-1-37.

[Source: Renumbered from 165:26-18-1 at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 33 Ok Reg 615, eff 8-25-16; Amended at 34 Ok Reg 958, eff 9-11-17; Amended at 36 Ok Reg 580, eff 8-1-19]

165:26-1-37. Evidence of financial responsibility

Owners and operators of AST systems will provide evidence of financial responsibility through the mechanisms set forth below, or any other mechanism that is pre-approved by the Division Director of the PSTD:

- (1) Self insurance
- (2) Guarantee
- (3) Insurance
- (4) Surety bond
- (5) Letter of Credit
- (6) Trust fund or standby trust fund
- (7) Securities pledge
- (8) Cash or cash equivalent pledge

[Source: Renumbered from 165:26-18-3 at 23 Ok Reg 2297, eff 7-1-06]

PART 7. NOTIFICATION AND REPORTING REQUIREMENTS**165:26-1-41. General reporting requirements**

PSTD requires owners and/or operators of aboveground storage tank systems to provide information it deems necessary for the protection of human health, the environment and to assure the safety of people and property. Owners and operators must notify PSTD within thirty (30) days when their mailing address changes or when the status of the aboveground storage tank system changes. Use of the designated PSTD online format is required for reporting, scheduling, tank registration, change in ownership, thirty (30) day release detection, testing, temporary change in service, permanent closure, or return to service. Owners and operators of aboveground storage tanks must notify PSTD at least thirty (30) days prior to switching regulated substances containing greater than ten percent (10%) ethanol or twenty percent (20%) biodiesel in the online format established by PSTD. Required release detection forms are available on the Commission website.

Failure to notify and/or submit PSTD paperwork in the online format established by PSTD within the timeframe required may result in an enforcement action.

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 34 Ok Reg 958, eff 9-11-17; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 36 Ok Reg 580, eff 8-1-19; Amended at 37 Ok Reg 1143, eff 10-1-20]

165:26-1-42. New tank systems

(a) Persons intending to install a new aboveground storage tank and/or new aboveground or underground piping must give PSTD notification of the installation at least forty-eight (48) hours before the tank and/or lines are to be installed in the online format established by PSTD and receiving confirmation of the scheduled installation and the Temporary Authorization for Receipt of Fuel from PSTD. If events require the owner to change the date of installation, the Division should be given forty-eight (48) hours' notice of the new date. Any storage tank system permanent removal or a removal associated with replacement of tanks or lines requires at least fourteen (14) day notification prior to the removal activity.

(b) After the tank installation is complete, the PSTD registration must be submitted to PSTD in the online format established by PSTD along with copies of required installation testing, photographs of the tank and piping system components before they are covered, an as-built drawing of the entire tank system, and manufacturer installation checklists within thirty (30) days. The tank owner and the AST Installer are both responsible for timely submittal of all installation paperwork. The registration must be approved and tank fees paid in order to receive a tank permit to dispense fuel. No regulated storage tank system can be operated without a valid permit from the Corporation Commission.

(c) Owners and AST Installer must certify on the PSTD Registration that the installation of tanks and piping meet the requirements of this Chapter. A PSTD Certification of Installation Inspection Form may also be submitted to satisfy certification of tank and piping installation.

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 26 Ok Reg 1831, eff 7-1-09; Amended at 31 Ok Reg 1010, eff 9-12-14; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 33 Ok Reg 615, eff 8-25-16; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 36 Ok Reg 580, eff 8-1-19; Amended at 37 Ok Reg 1143, eff 10-1-20; Amended at 40 Ok Reg 1797, eff 10-1-23]

165:26-1-43. Existing tanks [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-1-44. Tank closure or change in service [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 33 Ok Reg 615, eff 8-25-16; Amended at 35 Ok Reg 1010, eff 10-1-18; Revoked at 39 Ok Reg 966, eff 10-1-

22]

165:26-1-45. Releases [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-1-46. Corrective action [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-1-47. Transfer of ownership

When the owner of an aboveground storage tank transfers ownership of the facility or tank to another person, the new owner must notify the Commission within thirty (30) days of the transfer. The notice must specify at a minimum, the name of the new owner, the location of the facility and the date of the transfer of ownership. In addition, the former owner must advise PSTD of the name and address of the new owner. All records required by PSTD must be transferred at no cost to the new owner. Owners and operators must notify PSTD within thirty (30) days when their mailing address changes.

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 35 Ok Reg 1010, eff 10-1-18]

165:26-1-48. Tank and line tightness testing

(a) Tank and line tightness test results in which any part of the tank system tested does not pass must be reported to PSTD within twenty-four (24) hours by the owner, operator, their employees or agents, and also independently by the person or company performing the test. Complete test results must be submitted within seven (7) days of the testing.

(b) Hydrostatic line tightness tests and line leak detector tests must be conducted by a licensed tester, if applicable, in accordance with manufacturer's instructions, and reported on the prescribed PSTD form.

(c) The licensed tester performing line and leak detector tests must also certify that the line leak detector is installed properly.

(d) All personnel performing tank and line testing must have the required license, education, experience, applicable certification, knowledge and competence to correctly perform testing services in accordance with the testing equipment, manufacturer certification and applicable industry standards or codes.

(e) Tank, line and line leak detector testing must be scheduled by submitting the PSTD scheduling form in the established online format and PSTD staff may be present.

[Source: Renumbered from 165:26-3-17 at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 31 Ok Reg 1010, eff 9-12-14; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 41 Ok Reg 1803, eff 10-1-24]

PART 9. RECORDKEEPING

165:26-1-55. Availability of records

- (a) Owners and operators of regulated aboveground storage tank systems must cooperate with PSTD requests for submission of inventory and monitoring records. All leak detection records, including sampling, testing, inventory and monitoring records must be available for each tank for at least the preceding twelve months. Copies of all records required pursuant to this Chapter must be kept at the facility and available for immediate inspection by the PSTD Fuel Specialist or be readily available upon request.
- (b) Failure to have the required records available when requested by PSTD may result in an enforcement action.
- (c) Release detection records must be maintained for a minimum of three (3) years on forms specified by PSTD.
- (d) When a change in an owner or operator of a petroleum storage tank system occurs, all records required by PSTD must be transferred at no cost to the new owner or operator.
- (e) Each owner/operator must provide written notice of any address change within 30 days to the PSTD office.

[Source: Renumbered from 165:26-3-11 at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 26 Ok Reg 1831, eff 7-1-09; Amended at 34 Ok Reg 958, eff 9-11-17]

165:26-1-56. Repair records

Owners and operators of regulated aboveground storage tank systems must maintain records that identify the location and nature of the repair, as follows:

- (1) Tank system repairs meant to restore a tank, pipe, spill prevention equipment, overfill prevention equipment, corrosion protection equipment, release detection equipment or other AST system component that has caused a release or a suspected release of product from the AST system or has failed to function properly must be scheduled using the OCC scheduling form.
- (2) These records shall include a complete description of all repairs made, photographs before and after repair, sample results if required, an updated site map, and testing following repairs.
- (3) The records must be readily available at the facility, submitted to PSTD within thirty (30) days of repair completion, and kept for the remaining operating life of the storage tank system.
- (4) Requirements of this Section do not apply to routine and minor maintenance activities related to the tank and piping system or dispensers.

[Source: Renumbered from 165:26-3-12 at 23 Ok Reg 2297, eff 7-1-06; Amended at 30 Ok Reg 586, eff 7-1-13; Amended at 35 Ok Reg 1010, eff 10-1-18]

165:26-1-57. Tank installation, closure and removal records

- (a) Owners and operators of aboveground storage tank systems must maintain records regarding the installation for the lifetime of the system; or, at the owner's option, give copies of installation records to PSTD for retention in the Division's files. Owners who have purchased systems must maintain the installation information if it is available.
- (b) Owners and operators of aboveground storage tank systems must maintain records capable of demonstrating compliance with the closure and removal requirements for tanks that are temporarily taken out of service or permanently removed at operating facilities.
- (c) The owner, operator or Commission licensee hired by the owner and/or operator must submit the PSTD Closure Report Form and all required attachments to PSTD within forty-five (45) days

from the date the tanks are permanently closed.

[Source: Renumbered from 165:26-3-13 at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 26 Ok Reg 1831, eff 7-1-09; Amended at 36 Ok Reg 581, eff 8-1-19]

165:26-1-58. Release detection and corrosion protection records

(a) Owners and operators of regulated aboveground storage tank systems must maintain release detection records for a minimum of three (3) years.

(b) Owners and operators of regulated aboveground storage tank systems who use cathodic protection ("CP") must maintain the following records:

(1) Original cathodic protection design with drawings, plans, description of materials used, and suitability study depicting all of the cathodic protection system components in accordance with National Association of Corrosion Engineers (NACE) RP0285.

(2) Suitability study performed to determine if a tank could be upgraded with corrosion protection.

(3) Rectifier readings for impressed current systems conducted at least every 60 days on the appropriate OCC form.

(4) Results of the last three inspections or CP system tests completed by a licensed corrosion protection tester.

[Source: Renumbered from 165:26-3-14 at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 34 Ok Reg 958, eff 9-11-17; Amended at 41 Ok Reg 1803, eff 10-1-24]

165:26-1-59. Spill and overflow records

Owners and operators of aboveground storage tank systems must keep records of spills and overfills for review and inspection by PSTD for a period of 3 years.

[Source: Renumbered from 165:26-3-15 at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08]

165:26-1-60. Piping records

Tank owners must maintain a current map of their underground piping if that information is available to them and update it within 30 days of any changes.

[Source: Renumbered from 165:26-3-16 at 23 Ok Reg 2297, eff 7-1-06]

165:26-1-61. Inventory records [REVOKED]

[Source: Renumbered from 165:26-3-18 at 23 Ok Reg 2297, eff 7-1-06; Revoked at 25 Ok Reg 2187, eff 7-11-08]

PART 11. FEES

165:26-1-70. Fees

This Chapter requires fees according to the schedule set out in Chapter 5 of Commission rules.

[Source: Renumbered from 165:26-1-30.4 at 23 Ok Reg 2297, eff 7-1-06; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 33 Ok Reg 615, eff 8-25-16; Amended at 35 Ok Reg 1010, eff 10-1-18]

PART 13. SHUTDOWN OF OPERATIONS

165:26-1-90. Shutdown of operations

- (a) PSTD may close (shut down) a system:
- (1) If the system poses an imminent threat to health, safety, or the environment.
 - (2) If the owner or operator is operating tanks for which permit fees have not been paid.
 - (3) If the owner or operator fails to comply with a Commission requirement or order.
 - (4) For failure to properly install, operate and/or maintain leak detection, spill, overfill, or corrosion equipment if the owner/operator has been issued a written Notice of Violation ("NOV") and has failed to correct the problem.
 - (5) Failure to protect a buried metal flexible connector from corrosion if the owner/operator has been issued a written Notice of Violation ("NOV") and has failed to correct the problem.
 - (6) Failure to perform, maintain, have readily available or present records for the previous twelve (12) thirty (30) day periods.
 - (7) Tampering with equipment.
 - (8) If a Fuel Specialist issues a Notice of Violation ("NOV") and the violation(s) is not corrected.
- (b) PSTD must close (shut down) a system:
- (1) If required spill prevention equipment is not installed.
 - (2) If required overfill protection equipment is not installed.
 - (3) If required leak detection equipment is not installed.
 - (4) If required corrosion equipment is not installed.
 - (5) If two inches (2") or more of water is found in the tank where conventional gasoline or diesel fuel is stored and if one-half inch (1/2") or more of water is found in the tank of gasoline blended with alcohols, E85 fuel ethanol, or diesel blended with biodiesel.
 - (6) If meter is found to be off in calibration by more than minus fifteen (-15) cubic inches per every five (5) gallons.
- (c) Only PSTD designated employees have the authority to lock or seal dispensers and/or fill pipes of any system violating subsection (a) or (b) of this Section. The PSTD employee must explain in writing to the owner or operator the reason the AST system is being locked or sealed.
- (d) The PSTD "Out of Order" tag attached to each fill pipe of the tank(s) in violation shall serve to clearly identify the tank(s) as ineligible for delivery, deposit, or acceptance of product. Tank owners/operators and product deliverers are responsible for ensuring that product is not delivered into the tagged tank(s).
- (e) Any person who removes a lock or seal without permission from PSTD will be subject to penalties imposed by this Chapter, or formal enforcement proceedings.
- (f) Upon confirmation that the AST system no longer poses an imminent threat to health, safety, or the environment, the owner and/or operator of the facility is in compliance with PSTD rules, permit fees paid, violation(s) corrected, or Commission order requirements satisfied, the authority to remove a lock or seal by the owner or operator may be obtained as follows:
- (1) Written permission from the PSTD employee who placed the lock or seal on the device; coupled with written confirmation to PSTD by the person removing the lock or seal; or

- (2) Verbal or written permission from the Director or Director's designee; or
 - (3) Application to and order of the Commission.
- (g) If a facility is closed under the provisions of this Section, the owner or operator of the facility will be afforded a hearing within ten (10) days of receipt by PSTD of the owner's or operator's application for a hearing.

[Source: Added at 25 Ok Reg 2187, eff 7-11-08; Amended at 30 Ok Reg 586, eff 7-1-13; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 33 Ok Reg 615, eff 8-25-16; Amended at 34 Ok Reg 958, eff 9-11-17; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 36 Ok Reg 581, eff 8-1-19]

PART 15. LICENSING PROCEDURES

165:26-1-110. Licensing procedure for AST Installers

- (a) Any individual who would like to become an AST Installer must:
- (1) Complete an OCC AST Installer application form.
 - (2) Provide sufficient proof of two (2) years' related work experience, completed within the last five (5) years. Applicants must have active participation in the completion of at least three (3) aboveground storage tank installations. If applicant is a current AST installer license holder in another state, the work experience from another state may be substituted for each confirmed year he or she held the license.
 - (3) Pass an examination approved by PSTD.
 - (4) Pay fees for applications, examinations, and licensing prior to examination and license issuance as set forth in OAC 165:5.
 - (5) Certify that he or she will comply with all Commission rules and requirements for aboveground storage tanks, and applicable Occupational Safety and Health Administration (OSHA) 29 CFR 1910.120 Hazardous Waste Operations and Emergency Response (HAZWOPER) standards.
- (b) All examinations and licensing procedures must be completed within one (1) year of approval of the application. Failure to complete the exam and licensing procedures will result in forfeiture of fees and will require a new application and appropriate fees.
- (c) Continuing education is required to maintain an AST Installer license; this consists of four (4) hours of continuing education through a PSTD approved program every year. Licensees may request to rollover a maximum of four (4) credit hours from the current year to satisfy the following year's continuing education requirements. Approval of any rollover hours will be at the discretion of PSTD after evaluating the class, course, or seminar.

[Source: Renumbered from 165:26-1-30.3 at 25 Ok Reg 2187, eff 7-11-08; Amended at 30 Ok Reg 586, eff 7-1-13; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 36 Ok Reg 581, eff 8-1-19; Amended at 40 Ok Reg 1797, eff 10-1-23]

165:26-1-110.1. Licensing procedure for AST Removers

- (a) Any individual who would like to become a licensed AST Remover must:
- (1) Complete an OCC AST Remover application form.
 - (2) Provide sufficient proof of two (2) years related work experience, completed within the last five (5) years. Applicants must have active participation in the completion of at least three (3) AST removals. If applicant is a current AST remover license holder in another state, the work

experience from another state may be substituted for each confirmed year he or she held the license.

(3) Pass an examination approved by the PSTD.

(4) Pay fees for applications, examinations, and licensing prior to examination and license issuance as set forth in OAC 165:5.

(5) Certify that he or she will comply with all Commission rules and requirements for removal of aboveground storage tanks, and applicable Occupational Safety and Health Administration (OSHA) 29 CFR 1910.120 Hazardous Waste Operations and Emergency Response (HAZWOPER) standards.

(b) All examinations and licensing procedures must be completed within one (1) year of approval of the application. Failure to complete the exam and licensing procedures will result in forfeiture of fees and will require a new application and appropriate fees.

(c) Continuing education is required to maintain an AST Removers license; this consists of four (4) hours of continuing education through a PSTD-approved program every year. Licensees may request to rollover a maximum of four (4) credit hours from the current year to satisfy the following year's continuing education requirements. Approval of any rollover hours will be at the discretion of PSTD after evaluating the class, course, or seminar.

[Source: Added at 40 Ok Reg 1797, eff 10-1-23]

165:26-1-110.2. Licensing Procedures for Testers

(a) Any individual who would like to become an OCC Licensed Tester must submit the following in accordance with a format established by PSTD:

(1) Complete the OCC tester's Licensed Tester application form.

(2) Submit applicable certifications for the type of testing they wish to be licensed for.

(3) Sump testing, sensor testing, spill bucket testing and overflow testing will require proof that applicant has passed the PEI RP 1200 exam.

(4) Tank testing, line testing, corrosion protection testing, leak detector testing, and ATG testing applicants must provide certifications.

(5) Fees must be paid in accordance with OAC 165:5.

(b) No individual shall test an AST system unless that individual is licensed as required by this Chapter.

[Source: Added at 41 Ok Reg 1803, eff 10-1-24]

165:26-1-111. Licensee disciplinary action procedure

A license issued by PSTD is a designation of competence to the public in the area of licensee expertise. PSTD is not limited to, but may use the following disciplinary action for PSTD licensees:

(1) **Informal reprimand.** The Manager of the appropriate PSTD department will call offending licensee for an informal discussion addressing the recent infraction and place a memo in the licensee's file documenting the discussion and nature of the violation.

(2) **Formal reprimand.** The Manager of the appropriate PSTD department will prepare a letter of reprimand to the licensee addressing the offense. The letter of reprimand will provide the licensee an opportunity to formally dispute alleged violation(s). The reprimand letter, licensee's response, all recourse actions following licensee rebuttal, if any, and the Manager's final decision(s) will be placed in the licensee's file and maintained by PSTD.

(3) **License suspension, revocation and/or refusal to renew a license.** If the Director elects to pursue suspension, revocation, or refusal to renew, a notice of such action will be sent to the licensee by certified mail/return receipt requested. The notice will state the date and time of

the hearing scheduled before an Administrative Law Judge.

[Source: Added at 36 Ok Reg 582, eff 8-1-19]

165:26-1-113. License penalties

(a) PSTD shall have the responsibility to deny, suspend, refuse to renew or revoke the license of, or reprimand, any licensee who is found in violation of:

(1) The practice of any fraud or deceit in obtaining a license or in performing work pursuant to this Chapter.

(2) Any gross negligence, incompetence or misconduct in work performed pursuant to this Chapter.

(3) Knowingly making false statements or signing false statements, certificates or affidavits to PSTD or to clients.

(4) Aiding or assisting another person in violating any provision of this Chapter.

(5) Signing a verification statement for work performed pursuant to this Chapter which was not performed by the aboveground storage tank licensee.

(6) Engaging in dishonorable, unethical or unprofessional conduct of a character likely to deceive, defraud or harm a customer or the public.

(7) Failure to comply with this Chapter, OAC 165:25, OAC 165:27, OAC 165:29, and/or the Oklahoma Petroleum Storage Tank Consolidation Act (17 O.S. §§ 301 et seq.) may result in PSTD seeking a suspension and/or revocation of the license.

(8) Being under indictment or convicted of a felony for any criminal offense that impacts their obligation to PSTD.

(b) Failure to submit Commission required paperwork, test results, and reports in the online format established by PSTD within the required timeframe may result in enforcement action.

(c) Disciplinary action levels against PSTD licensees include but are not limited to informal reprimand, formal reprimand, license suspension, license revocation and refusal to renew.

(d) Any licensee in violation of Commission enabling statutes, PSTD rules, requirements and/or Commission orders may be subject to disciplinary action levels mentioned above and/or fines assessed by the Commission after notice and hearing.

[Source: Added at 32 Ok Reg 794, eff 8-27-15; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 36 Ok Reg 582, eff 8-1-19; Amended at 37 Ok Reg 1143, eff 10-1-20; Amended at 41 Ok Reg 1803, eff 10-1-24]

PART 17. OPERATOR TRAINING [REVOKED]

165:26-1-130. Training requirements [REVOKED]

[Source: Added at 25 Ok Reg 2187, eff 7-11-08; Revoked at 34 Ok Reg 958, eff 9-11-17]

165:26-1-132. Operator Class designations [REVOKED]

[Source: Added at 25 Ok Reg 2187, eff 7-11-08; Revoked at 34 Ok Reg 958, eff 9-11-17]

SUBCHAPTER 2. GENERAL REQUIREMENTS FOR ABOVEGROUND

STORAGE TANK SYSTEMS**PART 1. DESIGN AND INSTALLATION****165:26-2-1. Approved tanks, tank design [RENUMBERED TO 165:26-2-1.3]**

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Renumbered to 165:26-2-1.3 at 23 Ok Reg 2297, eff 7-1-06]

165:26-2-1.1. Aboveground storage tank installation

All tanks, piping, and associated equipment used in conjunction with an AST installation shall be installed by personnel possessing appropriate skills, experience, applicable certification, and required PSTD license to complete the installation in accordance with recognized industry standards and this Chapter. An AST Installer must be present at all times during the installation. The PSTD Fuel Specialist monitoring the installation must be contacted before underground piping is backfilled so piping and sump tests may be observed and/or inspected. Photos of the installation of tank(s) and line(s) must accompany a completed registration form within thirty (30) days of installation and tank fees must be paid before a permit is issued.

[Source: Added at 23 Ok Reg 144, eff 10-6-05 (emergency); Added at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 40 Ok Reg 1797, eff 10-1-23]

165:26-2-1.2. Compatibility [REVOKED]

[Source: Renumbered from 165:26-2-172 at 23 Ok Reg 2297, eff 7-1-06; Revoked at 25 Ok Reg 2187, eff 7-11-08]

165:26-2-1.3. Approved tanks, tank design

- (a) The material and construction of the tank must be compatible with the material stored and the conditions of storage such as pressure and temperature.
- (b) Underground tanks installed for aboveground use prior to July 1, 2007 may be used if installed inside secondary containment.
- (c) Only tanks designed for aboveground use may be installed aboveground after July 1, 2007.
- (d) Product lines must be installed above the maximum liquid level except for vertical tanks may have bottom openings if installed inside concrete secondary containment and meet all other general provisions in accordance with this Chapter.

[Source: Renumbered from 165:26-2-1 at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 26 Ok Reg 1831, eff 7-1-09; Amended at 35 Ok Reg 1010, eff 10-1-18]

165:26-2-2. Emergency pressure release [REVOKED]

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Revoked at 25 Ok Reg 2187, eff 7-11-08]

165:26-2-3. Aboveground storage tank spacing

Spacing (shell to shell) between any two adjacent aboveground tanks for tanks storing Class I, II, or IIIA stable liquids must be according to the standards in NFPA 30. The minimum distance between tanks shall be no less than 3 feet. Variances can be made by PSTD for pre-existing facilities where deviation from these rules does not pose a serious hazard to people or property.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 37 Ok Reg 1143, eff 10-1-20]

165:26-2-4. Distance to be kept around tanks

- (a) The following distances, at a minimum, must be kept around aboveground storage tanks.
- (1) 50 ft (15 meters) from the nearest important building as defined by this Chapter;
 - (2) 50 ft (15 meters) from any fuel dispenser;
 - (3) 50 ft (15 meters) from the nearest side of a public way; and
 - (4) 100 ft (30 meters) from any property line that is or might be built upon, including the opposite side of a public way.
- (b) The distances as set forth in (a) of this may be reduced by 50 percent if the tanks are fire-resistant. The distances as set forth in (a) may be further reduced if the tanks are a fire-protected tank or tanks in vaults as per NFPA 30A-4.3.2.4.
- (c) A variance may be granted for pre-existing facilities where compliance would be difficult and expensive and the current distances between tanks, property lines or dispensers pose no serious threat to people or property.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 36 Ok Reg 583, eff 8-1-19; Amended at 37 Ok Reg 1143, eff 10-1-20]

165:26-2-5. Requirements on fill pipes

- (a) Each fill pipe must be identified by a tag or other marking to identify the product for which the tank is used. The marking must be maintained in legible condition throughout the life of the tank. Color-coding may also be used in addition to marking.
- (b) If the fill pipe is located within the containment dike a spill bucket is not required.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 144, eff 10-6-05 (emergency); Amended at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08]

165:26-2-5.1. General spill and overflow prevention requirements

- (a) Owners and operators of aboveground storage tank systems, their employees or agents, as well as those who transport regulated substances to these systems must do everything reasonably possible to ensure that releases due to spilling and overfilling do not occur.
- (b) Tanks with a fill pipe must be filled through a liquid tight connection mounted inside at least a five (5) gallon spill container. A spill bucket is not required if the fill pipe is located within an impervious containment dike. Where an aboveground tank is filled by means of fixed piping, either a check valve and shutoff valve with a quick-connect coupling or a check valve with a dry-break coupling shall be installed in the piping at a point where connection and disconnection is made inside the spill containment between the tank and the delivery vehicle. This device shall be

protected from tampering and physical damage. Tampering with equipment is prohibited. Any violation of this section may result in fines, enforcement action and/or shutdown of operations.

(c) For existing aboveground storage tank systems installed before October 13, 2018, any one of the following methods must be used to prevent overfilling.

(1) High liquid level alarms with an audible or visual signal that alerts personnel when the tank reaches ninety percent (90%) capacity at a constantly attended operation or surveillance station.

(2) High liquid level pump cutoff devices set to stop flow at a predetermined container content level.

(3) Direct audible or code signal communication between the tank gauger and the pumping station.

(4) A fast response system for determining the liquid level of each bulk storage container such as digital computers, telepulse, or direct vision gauges. If this alternative is used a second person must be present to monitor gauges and the overall filling of the tank.

(d) For installations after October 13, 2018, a fill valve which automatically stops delivery of liquid when the tank reaches ninety-five percent (95%) capacity in addition to one of the following methods must be used to prevent overfilling.

(1) High liquid level alarms with an audible or visual signal that alerts personnel when tank reaches ninety percent (90%) capacity at a constantly attended operation or surveillance station.

(2) Direct audible or code signal communication between the tank gauger and the pumping station.

(3) A fast response system for determining the liquid level of each bulk storage container such as digital computers, telepulse, or direct vision gauges. If this alternative is used, a second person must be present to monitor gauges and the overall filling of the tank.

(e) Liquid level sensing devices must be tested at least annually to ensure proper operation.

(f) Means shall be provided for determining the liquid level in each tank and this means shall be accessible to the delivery operator. Tank filling shall not begin until the delivery operator has determined that the tank has sufficient available capacity (ullage).

[Source: Amended and renumbered from 165:26-3-21 at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 34 Ok Reg 958, eff 9-11-17; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 36 Ok Reg 583, eff 8-1-19; Amended at 37 Ok Reg 1143, eff 10-1-20]

165:26-2-6. Vent piping requirements

(a) For installations after October 13, 2018, each tank and each compartment of a compartment tank shall have both normal and emergency venting. The vent opening shall be in addition to the fill, withdrawal, and liquid level gauge opening.

(b) Normal vents must be sized in accordance with either:

(1) UL new tank manufacturing standards

(2) API new tank manufacturing standards

(3) API 2000, Venting Atmospheric and Low-Pressure Storage Tanks, or

(4) Other accepted standards; or

(5) Must be at least as large as the filling or withdrawal connection, whichever is larger, but in no case less than 1 1/4 in. (7 centimeters) nominal inside diameter.

(c) Emergency vents must be sized in accordance with either:

(1) UL new manufacturing standards

(2) API new tank manufacturing standards

- (3) API 2000, Venting Atmospheric and Low-Pressure Storage Tanks, or
 - (4) Appendix I, or
 - (5) Other accepted standards.
- (d) Where vent pipe outlets for tanks storing Class I liquids are adjacent to buildings or public ways, they must be located so that the vapors are released at a safe point outside of buildings and not less than 12 ft. (3.6 meters) above the adjacent ground level.
- (e) In order to aid in dispersion, vapors must be discharged upward. Vent outlets must be located so that flammable vapors will not be trapped by eaves or other obstructions and be at least 5 ft. (1.5 meters) from building openings.
- (f) Vent pipes that are provided for normal tank venting must extend at least 12 ft. (3.6 meters) above ground level or 5 ft. above the roof line at the highest point of attachment.
- (g) Total venting capacity must be sized in accordance with:
- (1) UL new manufacturing standards
 - (2) API new manufacturing standards
 - (3) Wetted area calculations per tank design, and
 - (4) Appendix I, or
 - (5) Other approved method.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 34 Ok Reg 958, eff 9-11-17]

165:26-2-7. Collision barriers

- (a) Aboveground storage tanks exposed to traffic must be resistant to damage from the impact of a motor vehicle by suitable collision barriers. The secondary containment dike may serve as a collision barrier provided that it cannot be penetrated by a motor vehicle.
- (b) When guard posts or collision barriers are installed, the following design shall be acceptable:
- (1) They shall be constructed of steel not less than 4 in. (100 millimeters) in diameter and shall be filled with concrete.
 - (2) They shall be spaced not more than 4 ft. (1.2 meters) on center.
 - (3) They shall be set not less than 3 ft (0.9 meters) deep in a concrete footing of not less than 15-in. (380 millimeters) diameter.
 - (4) They shall not be less than three feet (3') above grade and concrete barriers not less than thirty-two inches (32") above grade.
 - (5) They shall not be less than five feet (5') from the tank shell.
- (c) Dispensing devices, except those attached to containers, must either be mounted on a concrete island or otherwise protected against collision damage by suitable means and must be securely bolted in place. If located indoors, the dispensing device will be located in a position where it cannot be struck by a vehicle that is out of control descending a ramp or other slope. The installation must be in accordance with the manufacturer's instructions.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 37 Ok Reg 1143, eff 10-1-20]

165:26-2-8. Installation testing

- (a) A tightness test must be completed on tank and lines during construction and before being put into service after the lines have been covered. Installation testing may be conducted by the licensed AST Installer unless otherwise noted.

- (1) All aboveground storage tanks must be tested to manufacturer's instructions. Single-wall tanks shall be air tested, soaped, and inspected for bubbling prior to installation. Double-wall tanks with a vacuum on the interstice: Check vacuum gauge to determine if the vacuum meets all minimum requirements set by the tank manufacturer. An air soap test is not required if the interstice vacuum meets tank manufacturer requirements.
- (2) Aboveground product piping shall be subjected to an air test of at least 50 psi. The test must have a duration of not less than 60 minutes. All piping joints must be soaped while the system is under pressure, in order to detect any possible leaks. The interstice area of double-wall piping must be tested according to the manufacturer's instructions.
- (3) All suction product piping must be tested while disconnected from the pumps, and dispensing units. The piping must be subjected to an air test of at least 50 psi. The test must have a duration of not less than 60 minutes. All piping joints must be soaped while the system is under pressure, in order to detect any possible leaks. The interstice area of double-wall piping must be tested according to the manufacturer's instructions.
- (4) All pressurized piping must be tested while connected to tanks, pumps and dispensing units if installed at the time of installation. The piping must be subjected to an air test of at least 50 psi. The test must have a duration of not less than 60 minutes. All piping joints must be soaped while the system is under pressure, in order to detect any possible leaks. The interstice area of double-wall piping must be tested according to the manufacturer's instructions.
- (5) All piping should be air tested and monitored continuously during the installation.
- (6) All underground pressurized and suction piping must have a precision tightness test performed after all paving over the piping has been completed and before the system is placed in operation. The precision tightness test must be performed by a licensed tester, and in accordance with manufacturer's instructions. The product line(s) must be hydrostatic tested by a NWGLDE approved testing device capable of detecting a leak of 0.10 gallons per hour with a test pressure of 50 psi or 1½ times the operating pressure, whichever is greater. The lines must be tested for a minimum of one hour.
- (7) Mechanical and electronic leak detector(s) must be tested for function by a licensed tester simulating a leak and operate in accordance with manufacturer's instructions.
- (8) If an ATG system with electronic line leak detector(s) is installed it must complete a leak detector test in each of the modes in which it is certified as capable of detecting a leak (e.g. 3gph, 0.2gph, and 0.1gph).
- (9) Containment sumps must be tested at installation by the licensed AST installer or a licensed tester after all piping and conduit has been installed by using vacuum, pressure, or liquid testing in accordance with one of the following criteria:
 - (A) Requirements developed by the manufacturer (owners and operators may use this option only if the manufacturer has developed requirements);
 - (B) Code of practice developed by a nationally recognized association or independent testing laboratory, e.g., PEI RP 1200.
- (10) Overfill prevention equipment must be inspected for proper operation at installation in accordance with one of the following criteria:
 - (A) Requirements developed by the manufacturer (owners and operators may use this option only if the manufacturer has developed requirements); or
 - (B) Code of practice developed by a nationally recognized association or independent testing laboratory, e.g., PEI RP 1200.

[Source: Amended and renumbered from 165:26-2-171 at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 34 Ok Reg 958, eff 9-11-17; Amended at 39 Ok Reg

967, eff 10-1-22; Amended at 41 Ok Reg 1803, eff 10-1-24]

PART 3. SECONDARY CONTAINMENT

165:26-2-31. Double-walled tanks

Double-walled tanks do not require additional containment if all the following conditions are met:

- (1) The capacity of the tank does not exceed 50,000 gallons (189,000 liters).
- (2) All piping connections to the tanks are made above the normal maximum liquid level.
- (3) A mechanism is provided to prevent the release of liquid from the tank by siphon flow.
- (4) A mechanism is provided for determining the level of liquid in the tank, which is accessible to the delivery operator.
- (5) A mechanism is provided to prevent overfilling by sounding an alarm when the liquid level in the tank reaches 90 percent of capacity and by automatically stopping the delivery of liquid to the tank when the level in the tank reaches 95 percent of capacity. In no case will these provisions restrict or interfere with the proper functioning of the normal vent or the emergency vent.
- (6) Spacing between adjacent tanks is not less than 3 ft (0.9 meters).
- (7) The tank is capable of resisting damage from the impact of a motor vehicle or suitable collision barriers are provided in locations where the tank is exposed to traffic.
- (8) Where the interstitial space is enclosed, it is provided with emergency venting.
- (9) A means is provided to establish the integrity of the interstitial space of the double wall tank.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 33 Ok Reg 615, eff 8-25-16]

165:26-2-32. Secondary containment

- (a) Aboveground storage tanks, other than those with double walls as set out in 165:26-2-31, must have secondary containment for the fuels stored in them.
- (b) Multiple products stored within the same containment area must be compatible with each other.
- (c) If the secondary containment area is open to precipitation, it must be able to contain 110 percent of the capacity of the largest tank plus the volume displaced by other tanks within the containment area.
- (d) The secondary containment area must be constructed with materials that are compatible with the product being stored.
- (e) The secondary containment area cannot have any uncapped drain that extends outside of the containment.
- (f) The secondary containment must be kept intact and free of vegetation, trash, water, and all other items not necessary for fuel storage.
- (g) Secondary containment can be made from native soil if the soil meets or exceeds the permeability rates listed in Appendix J, or it can be made of concrete or steel. Generally, soil containment may be preferred in open rural areas and concrete in more congested urban areas. In either case the secondary containment must be impermeable for the products stored in the tanks:
 - (1) When concrete is used for secondary containment the concrete must be suitable to contain the released product for as long as it would take to recover the release.

- (2) Soil containment not meeting the permeability rates listed in Appendix J must be made impermeable by use of a synthetic membrane liner made of rubber, plastic, or a geosynthetic clay liner.
- (3) A double-walled tank would meet the criteria of secondary containment.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 23 Ok Reg 144, eff 10-6-05 (emergency); Amended at 23 Ok Reg 2297, eff 7-1-06]

165:26-2-32.1. Spill Prevention, Control and Countermeasure Plan

- (a) Owners of aboveground storage tanks must comply with the Spill Prevention Control and Countermeasure (SPCC) rule found in Title 40 of the Code of Federal Regulations (CFR), Part 112 (Oil Pollution Prevention). If a Spill Prevention Control and Countermeasure (SPCC) plan is required, it must be kept on site.
- (b) The registered Professional Engineer or person responsible for preparation of plan must certify that plan has been prepared in accordance with good engineering practice, including consideration of applicable industry standards and the requirements of 40 CFR 112; procedures for required inspections and testing must be established; and the plan must be adequate for the facility.

[Source: Renumbered from 165:26-3-22 at 23 Ok Reg 2297, eff 7-1-06; Amended at 26 Ok Reg 1831, eff 7-1-09]

PART 4. REQUIREMENTS FOR CORROSION PROTECTION SYSTEMS

165:26-2-40. Corrosion protection

- (a) Any portion of a tank or its piping system that is in contact with the soil must be protected from corrosion by a properly engineered, installed and maintained cathodic protection system in accordance with recognized standards of design, such as:
 - (1) American Petroleum Institute Publication 1632-2002, Cathodic Protection of Underground Petroleum Storage Tanks and Piping Systems;
 - (2) National Association of Corrosion Engineers Standard RP0193-2001, Recommended Practice of External Cathodic Protection of On-Grade Metallic Storage Tank Bottoms;
 - (3) National Association of Corrosion Engineers Standard SP0169-2013, Control of External Corrosion of Underground or Submerged Metallic Piping Systems;
 - (4) National Association of Corrosion Engineers Standard SP0285-2011, Control of External Corrosion on Metallic Buried, Partially Buried, or Submerged Liquid Storage Systems; and
- (b) Approved or listed corrosion-resistant materials or systems include special alloys, fiberglass reinforced plastic, or fiberglass reinforced plastic coatings.
- (c) Piping systems for liquids, both aboveground and underground, that are subject to external corrosion must be protected.

[Source: Renumbered from 165:26-3-80 at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 33 Ok Reg 615, eff 8-25-16; Amended at 34 Ok Reg 958, eff 9-11-17]

165:26-2-41. Compliance with corrosion protection requirements and manufacturer's specifications

Corrosion protection systems must be operated and maintained in accordance with the

manufacturer's instructions and specifications to provide continuous corrosion protection to the metal components of the storage tank system that are routinely in contact with the ground. If any portion of an AST or metallic piping comes in contact with an electrolyte (dirt, sand, gravel, etc.), cathodic protection should be applied to assist in the control of corrosion. The amount of metal in contact with the electrolyte will determine the appropriate selection of cathodic protection; either galvanic anodes or an impressed current system. The selected cathodic protection system will be designed by a corrosion expert or a qualified engineer trained in the field of cathodic protection.

[Source: Renumbered from 165:26-3-81 at 23 Ok Reg 2297, eff 7-1-06]

165:26-2-42. Frequency and criteria of inspections and tests

- (a) All cathodic protection systems must be tested within six (6) months of installation and/or repair, and at least once every three (3) years thereafter by a licensed cathodic protection tester.
- (b) Cathodic protection testing, repair, or three (3) year recertification must be scheduled by submitting the PSTD scheduling form and PSTD staff may be present
- (c) Every sixty (60) days impressed current cathodic protection systems must be inspected by the owner or owner's designated representative to ensure the equipment is working properly.
- (d) The criteria used to determine whether cathodic protection is adequate must be in accordance with a code of practice developed by a nationally recognized organization, such as the National Association of Corrosion Engineers (NACE) SP0285.
- (e) All personnel performing cathodic protection system testing must have the required license, education, current corrosion certification experience, knowledge and competence to correctly perform testing services in accordance with a certified course and applicable industry standards or codes.

[Source: Renumbered from 165:26-3-82 at 23 Ok Reg 2297, eff 7-1-06; Amended at 31 Ok Reg 1010, eff 9-12-14; Amended at 36 Ok Reg 583, eff 8-1-19; Amended at 41 Ok Reg 1803, eff 10-1-24]

PART 5. PIPING

165:26-2-51. Piping protection

Piping must be located for maximum practical protection from physical damage.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04]

165:26-2-52. Piping and gravity flow

Where tanks are at an elevation that produces a gravity head on the dispensing device, the tank outlet must be equipped with an anti-siphon device such as a solenoid valve, positioned adjacent to and downstream from the emergency valve, installed and adjusted so that liquid cannot flow by gravity from the tank in case of piping or hose failure when the dispenser is not in use.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 34 Ok Reg 958, eff 9-11-17]

165:26-2-53. Valves on piping

- (a) If a submersible pump system is used, a UL listed emergency shutoff/shear valve must be installed at each dispensing device. Both the emergency shutoff/shear valve and dispensing device

shall be rigidly anchored in place.

(b) If a suction pump-type dispensing device with an air eliminator is used, and where the height of liquid in the tank may exceed the height of the suction pump, a UL listed, vacuum-actuated shutoff/shear valve or equivalent-type valve must be installed directly under each dispensing device. Both the shut off/shear valve and dispensing device shall be rigidly anchored in place. Tanks installed in below-grade vaults are not required to comply with this requirement.

(c) Manual shutoff and check valves must be equipped with a pressure-relieving device that will relieve the pressure generated by thermal expansion back to the tank. Manual shutoff valves that are normally open and only closed for maintenance do not require a pressure relieving device.

(d) Each connection to an aboveground tank through which liquid normally flows must be provided with an internal or an external emergency fire valve located as close as practical to the shell of the tank or submerged pump. The fill line may be equipped with a check valve made of steel or nodular iron rather than a fire valve. The steel check valve must be installed downstream of the block valve on fill lines if a fire valve is not installed.

(e) An anti-siphon or solenoid valve must be installed on each supply line according to manufacturer guidance and recognized industry standards.

(f) A manual shut off or ball valve must be installed on each supply line according to manufacturer guidance and recognized industry standards.

(g) All valves must meet the construction criteria of 165:26-2-54.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 2297, eff 7-1-06; Amended at 34 Ok Reg 958, eff 9-11-17; Amended at 36 Ok Reg 584, eff 8-1-19]

165:26-2-54. Aboveground storage tank piping materials

(a) The design, fabrication, assembly, test and inspection of the piping system from the fuel tank to the fuel dispensers must be in accordance with the piping manufacturers installation recommendations and instructions.

(b) Pipes, valves, couplings, flexible connectors, fittings and other pressure containing parts must be installed in accordance with Petroleum Equipment Institute RP200, *Recommended Practices for Installation of Aboveground Storage Systems for Motor Vehicle Fueling*.

(c) Refer to Subchapter 8 for guidelines regarding over-water piping used at marinas.

(d) Valves at storage tanks and their connections to the tank must be of steel or nodular iron. Low melting point materials such as aluminum, copper, brass or non-ductile material such as cast iron may be used in aboveground piping provided that they are located downstream of an approved steel or nodular iron emergency valve that has been installed and located as close as practical to the shell of the tank or submerged pump.

(e) Valves at storage tanks may be other than steel or nodular iron if the valves are installed internal to the tank

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 144, eff 10-6-05 (emergency); Amended at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08]

165:26-2-55. Underground piping materials

(a) All new underground product piping and ancillary equipment installed at a new facility or existing facility must have the following characteristics:

- (1) Non-metallic;
 - (2) Double-walled;
 - (3) A tracer locator wire must be installed in all piping trenches; and
 - (4) Dispenser sumps must be installed and monitored with sensors as per OAC 165:26-3-20.2.
 - (5) Piping transition sumps must be installed and monitored with sensors if the interstice area of connecting piping cannot be connected in an approved manner.
- (b) Existing facilities that are replacing the lesser of twenty feet (20') or fifty percent (50%) of underground piping must upgrade pursuant to (a) of this Section. If a metallic line fails due to structural failure or corrosion, all metallic product lines at the facility must be removed, and cannot be repaired.
- (c) Existing facilities that are making any alteration to a fuel island when concrete removal is required must install dispenser sumps and monitor as pursuant to OAC 165:25-3-6.29. Repairs to the island that in no way change the island from its original design is not considered making alterations.
- (d) Existing facilities that are installing new dispensers must install under dispenser containment (UDC) sumps and monitor as pursuant to OAC 165:25-3-6.29. Dispensers will be considered new when both the dispenser and equipment needed to connect the dispenser to an AST system is installed. Check valves, shear valves, unburied risers or flexible connectors and other transitional components are considered equipment that connects a dispenser to an AST system.
- (e) Tracer locator wire is not required to be installed in existing piping trenches containing piping which otherwise meets the requirements in subsection (a) unless the trench is opened to repair, move, or replace the piping.
- (f) Existing facilities that are replacing aboveground storage tanks must replace all single walled piping per (a) of this section.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 144, eff 10-6-05 (emergency); Amended at 23 Ok Reg 2297, eff 7-1-06; Amended at 31 Ok Reg 1010, eff 9-12-14; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 36 Ok Reg 584, eff 8-1-19; Amended at 41 Ok Reg 1803, eff 10-1-24]

165:26-2-56. Installation and monitoring requirements for piping [AMENDED AND RENUMBERED TO 165:26-3-20.2]

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 144, eff 10-6-05 (emergency); Amended and renumbered to 165:26-3-20.2 at 23 Ok Reg 2297, eff 7-1-06]

165:26-2-57. Commission-approved alternative methods [RENUMBERED TO 165:26-3-20.3]

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Renumbered to 165:26-3-20.3 at 23 Ok Reg 2297, eff 7-1-06]

PART 7. VAULT REQUIREMENTS

165:26-2-71. Vaults

A vault is allowed above or below grade and must meet NFPA 30 and NFPA 30A

requirements.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 34 Ok Reg 958, eff 9-11-17]

PART 9. DISPENSER REQUIREMENTS

165:26-2-91. Dispensers

- (a) Liquids must be transferred from storage tanks by means of fixed pumps designed and equipped to allow control of the flow and prevent leakage or accidental discharge.
- (b) Dispensing devices for Class I and Class II liquids must be listed.
 - (1) Existing listed or labeled dispensing devices may be modified provided the modifications made are "Listed by Report" by an approved testing laboratory or as otherwise approved by PSTD.
 - (2) Modification proposals must contain a description of the component parts used in the modification and the recommended methods of installation on specific dispensing devices, and they must be made available to PSTD for approval prior to installation.
- (c) A control must be provided that will permit the dispenser to operate only when a dispensing nozzle is removed from its bracket or normal position with respect to the dispensing device and only when the switch on this dispensing device is manually actuated. This control must also stop the dispenser when all nozzles have been returned either to their brackets or to the normal non-dispensing position.
- (d) A UL listed emergency breakaway device designed to retain liquid on both sides of the breakaway point must be installed on each hose dispensing any class of liquids. These devices must be installed and maintained in accordance with the manufacturer's instructions. Where hoses are attached to a hose-retrieving mechanism, the listed emergency breakaway device must be installed between the point of attachment of the hose-retrieving mechanism to the hose and the hose nozzle valve.
- (e) All gasoline, gasoline-alcohol blends, gasoline-ether blends, E85 Fuel ethanol, and M85 methanol dispensers located at retail facilities shall have a ten (10) micron or smaller nominal pore-sized filter. All biodiesel, biodiesel blends, diesel, and kerosene dispensers located at retail facilities shall have a thirty (30) micron or smaller nominal pore-sized filter.
- (f) Dispensers installed after August 27, 2015, that are connected to aboveground piping must have sumps underneath the dispensers and be monitored. Dispensers that cannot meet these requirements must be in a contained area such as a dike.
- (g) New dispensers installed at motor fuel facilities must be located ten feet (10') or more from any building.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 30 Ok Reg 586, eff 7-1-13; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 34 Ok Reg 958, eff 9-11-17; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 36 Ok Reg 584, eff 8-1-19]

165:26-2-91.1. Display on dispenser

- (a) Every dispenser or delivery device regulated by the Commission used for sale of motor fuel to the public must have a label that clearly identifies every type of motor fuel offered for sale.

(b) Motor fuel containing fifteen percent (15%) ethanol, commonly referred to as E15, must be labeled as the following: The label is 3.625 inches (9.20 cm) wide x 3.125 inches (7.93 cm) long. "Helvetica Black" or equivalent type is used throughout. Use black letters on an orange background for the lower portion and the diagonal "Attention" field and use orange letters on a black background for the rest of the upper portion. Set vertical position and line spacing as appropriate for each field. The band at the top of the label contains the following:

(1) The band should measure 1.25 inch (3.175 cm) deep. The type in the band is centered both horizontally and vertically. The first line is the text "E15" and is in 42-point font. The second line is in 14-point font, at least 1/8 inch (.32 cm) below the first line and is in the text "Up to 15% ethanol".

(2) The type below the black band is left-justified. The first line is the text: "Use only in" and is in 20-point font. The second line is a bullet point, in 14-point font, at least 1/8 inch (.32 cm) below the first line and is the text: "2001 and newer passenger vehicles." The third line is a bullet point, in 14-point font, at least 1/8 inch (.32 cm) below the second line and is the text "Flex-fuel vehicles". The fourth line is in 12-point font, at least 1/8 inch (.32 cm) below the first line and is the text "Don't use in other vehicles, boats or gasoline- powered equipment. It may cause damage and is *prohibited* by Federal law." The word "prohibited" is bold and italic.

(c) Any other motor fuel must be displayed in accordance with 16 CFR Part 306.0 through 306.12, including Appendices; and sold as provided for by Commission rules and National Institute of Standards and Technology (NIST) Handbook 44, "Specifications, Tolerances, and Other Technical Requirements for Weighing and Measuring Devices".

[Source: Added at 37 Ok Reg 1143, eff 10-1-20; Amended at 41 Ok Reg 1803, eff 10-1-24]

165:26-2-92. Dispenser hose

(a) Listed hose assemblies must be used to dispense fuel.

(1) Hose length at facilities will not exceed eighteen feet (18') (5.5 m).

(2) Hose at retail and marina facilities must be checked daily for evidence of blistering, carcass saturation or separation, cuts, nicks or abrasions that expose reinforcement material and for slippage, misalignment or leaks at couplings.

(3) Hoses on dispensers that are connected to aboveground tanks within a fenced area may not exceed fifty feet (50') in length and must be secured, such as with a hose reel, to protect it from damage.

(b) If any defects are present, the defective hose must be immediately removed from service.

(c) At least once every thirty (30) days the hose must be completely extended and inspected.

(1) The hose couplings and the first twelve inches (12") of hose adjacent to the couplings must be examined.

(2) Structural weakness must be checked by pressing the hose in the area around its entire circumference for soft spots.

(3) Hoses that show evidence of soft spots must be immediately removed.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 35 Ok Reg 1010, eff 10-1-18]

165:26-2-93. Nozzles

At any installation where the normal flow of product may be stopped other than by the hose nozzle valve such as at pre-pay stations, the system must include listed equipment with a feature

that causes or requires the closing of the hose nozzle valve before product flow can be resumed or before the hose nozzle valve can be replaced in its normal position in the dispenser; or the hose nozzle valve must not be equipped with a latch-open device.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04]

PART 11. TANK FILLING PROCEDURES

165:26-2-111. Tank filling operation

A delivery vehicle must be separated from any aboveground tank by at least 25 ft. (7.6 m) if possible.

- (1) No minimum separation distance is required for tanks that are filled by gravity.
- (2) The required minimum separation distance will be reduced to 15 ft. (4.6 m) where the fuel being delivered is not a Class I liquid.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04]

PART 13. MISCELLANEOUS SAFETY PROVISIONS

165:26-2-131. Fencing

- (a) Tanks not enclosed in vaults must be enclosed with a chain link fence at least 6 ft. (2m) high. The fence must be separated from the tanks by at least 10 ft (3 m) and must have a gate that is secured against unauthorized entry.
- (b) The area within the fence must be kept free of vegetation, debris and any other material that is not necessary to the proper operation of the tank and piping system.
- (c) Tanks are not required to be enclosed within a fence if the property on which the tanks are located already has a perimeter security fence.
- (d) A fence may not be required if another method effectively restricts access to the tanks.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 23 Ok Reg 144, eff 10-6-05 (emergency); Amended at 23 Ok Reg 2297, eff 7-1-06]

165:26-2-132. Required signs

- (a) Warning signs must be conspicuously posted in the dispensing area incorporating the following or equivalent wording:
 - (1) WARNING.
 - (2) It is unlawful and dangerous to dispense gasoline into unapproved containers.
 - (3) No smoking.
 - (4) Stop motor.
 - (5) No filling of portable containers in or on a motor vehicle.
 - (6) Place container on ground before filling.
- (b) If blended ethanol or biodiesel product is dispensed, an OCC approved label must be displayed in a clear, conspicuous and prominent manner visible to customers using either side of the dispenser from which a blended ethanol or biodiesel product is dispensed.
- (c) A sign or label must be displayed in a clear, conspicuous and prominent manner when two (2) different types of gasoline are being dispensed from a single hose, e.g., one hundred percent (100%) gasoline and ten percent (10%) ethanol blend gasoline. The sign must be displayed in

close proximity to the one hundred percent (100%) gasoline button advising the customer that small amounts of ethanol may be dispensed in the first five (5) gallons of purchase of one hundred percent (100%) gasoline.

(d) Failure to abide with signage requirements may result in fines, formal enforcement action, or shutdown of operations.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 26 Ok Reg 1831, eff 7-1-09; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 33 Ok Reg 615, eff 8-25-16; Amended at 35 Ok Reg 1010, eff 10-1-18]

165:26-2-133. Sources of ignition

(a) Smoking materials, including but not limited to matches and lighters, must not be used within 20 ft. (6 m) of areas used for fueling, servicing fuel systems for internal combustion engines, or receiving or dispensing of Class I liquids.

(b) Conspicuous and legible signs prohibiting smoking must be posted within sight of the customer being served.

(c) The motors of all equipment being fueled must be shut off during the fueling operation, except for emergency generators, pumps, etc., where continuing operation is essential.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04]

165:26-3-134. Monitoring requirements [AMENDED AND RENUMBERED TO 165:26-3-20.1]

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 23 Ok Reg 144, eff 10-6-05 (emergency); Amended and renumbered to 165:26-3-20.1 at 23 Ok Reg 2297, eff 7-1-06]

PART 15. ELECTRICAL

165:26-2-151. Electrical requirements

(a) All electrical work must be performed by a licensed electrician.

(b) All electrical wiring and electrical utilization equipment must be of a type specified by and must be installed in accordance with NFPA 30A and NFPA 70, National Electrical Code.

(c) Clearly identified and easily accessible switch(es) or circuit breaker(s) must be provided at a location remote from dispensing devices, including remote pumping systems, to shut off the power to all dispensing devices in the event of an emergency. The switch or circuit breaker must be a minimum of twenty feet (20') and not more than one hundred feet (100') away from dispensing devices.

(d) Electrical equipment that was installed in compliance with an earlier state or national code will not require modification unless the equipment is hazardous to people or property.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 35 Ok Reg 1010, eff 10-1-18]

PART 17. INSTALLATION OF ABOVEGROUND STORAGE

TANK SYSTEMS [REVOKED]**165:26-2-171. Aboveground storage tank system installation [AMENDED AND RENUMBERED TO 165:26-2-8]**

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 144, eff 10-6-05 (emergency); Amended and renumbered to 165:26-2-8 at 23 Ok Reg 2297, eff 7-1-06]

165:26-2-172. Compatibility [RENUMBERED TO 165:26-2-1.2]

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Renumbered to 165:26-2-1.2 at 23 Ok Reg 2297, eff 7-1-06]

PART 19. REPAIRS TO ABOVEGROUND STORAGE TANK SYSTEMS**165:26-2-191. Repairs to aboveground tank systems**

Repairs to an aboveground storage tank system, excluding electrical work, must be performed by an AST Installer. Routine maintenance such as painting and repairs to a product dispensing unit will not be considered repairs to the storage tank system.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 40 Ok Reg 1797, eff 10-1-23]

PART 21. REMOVAL AND CLOSURE OF ABOVEGROUND STORAGE TANK SYSTEMS**165:26-2-210. Tank removal and closure**

- (a) Owners and Operators of all aboveground storage tank systems must notify the Petroleum Storage Tank Division at least fourteen (14) days prior to the removal or permanent closure of aboveground storage tanks and/or lines by submitting the PSTD scheduling form and receiving confirmation of the scheduled removal from PSTD. When scheduling a removal, a site map of where samples are to be taken should be attached to the scheduling form. If events require a change in the date of removal, the Division shall be given forty-eight (48) hours' notice prior to the new date.
- (b) An authorized agent of PSTD may be present to observe the removal and to inspect the closed tank system and the surrounding environment prior to backfilling.
- (c) Tanks, lines and ancillary equipment must be removed upon closure unless a Commission order grants a variance.
- (d) A licensed AST Remover must remove aboveground storage tank systems.
- (e) Photos must be taken of tank(s), line(s), and soil at removal. In the event there is a hole in a tank or line, further photographic evidence is required. If tank(s), line(s) or excavated soil show evidence of a release, photos of the apparent release must be taken that indicate the release source.

[Source: Added at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 33 Ok Reg 615, eff 8-25-16; Amended at 36 Ok Reg 585, eff 8-1-19; Amended at 40 Ok Reg 1797, eff 10-1-23; Amended at 41 Ok Reg 1803,

eff 10-1-24]

165:26-2-211. Compliance with removal and closure requirements

Owners and/or operators of aboveground storage tank systems that are temporarily taken out of service or permanently removed, must comply with all the requirements of this Part.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04]

165:26-2-212. Temporary removal from service

When an aboveground storage tank system is taken temporarily out of service, the owner or operator must:

- (1) Drain all fluid to less than one inch (1") of residue remaining in the tank.
- (2) Leave all vent lines open and functioning.
- (3) Cap and secure all other lines, pumps, manways and ancillary equipment.
- (4) Lock all fill caps.
- (5) Notify PSTD of a change in service on the prescribed form within thirty (30) days.
- (6) A TOU AST that has been out of service for more than twelve (12) months and cannot be returned to service is subject to the permanent closure requirements found in OAC 165:26-2-213.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 36 Ok Reg 585, eff 8-1-19; Amended at 41 Ok Reg 1803, eff 10-1-24]

165:26-2-212.1. Requirements for returning to service

- (a) All tanks out of service for more than twelve (12) months are required to be tightness tested and test results submitted to PSTD before returning to service.
- (b) A tightness test must be performed by a licensed tester and must be completed on the underground portion of out of service systems if more than twelve (12) months have elapsed since the last tightness test. Any system failure will require either closure or upgrade of the failed portion.
- (c) All systems out of service for more than twelve (12) months are required to meet all the requirements of this Chapter.
- (d) All underground storage tanks being used as aboveground storage tanks that have been out of service for more than twelve (12) months may not be returned to service.

[Source: Renumbered from 165:26-2-215 at 23 Ok Reg 2297, eff 7-1-06; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 36 Ok Reg 585, eff 8-1-19; Amended at 39 Ok Reg 967, eff 10-1-22; Amended at 41 Ok Reg 1803, eff 10-1-24]

165:26-2-213. Permanent closure

Owners and/or operators of aboveground storage tank systems who do not intend to use the tanks for fuel storage in the future must close the tank systems after they have been out of service for more than twelve (12) months by performing the following:

- (1) Empty, clean, purge and vapor free the tank of all flammable products and vapors.
- (2) Separate the piping from the tank. All underground piping and ancillary equipment must be removed unless a Commission order grants a variance.
- (3) Perform a site assessment pursuant to OAC 165:26-2-214, "Assessing the site at tank closure or change in service".

(4) A licensed AST Remover must be on site at all times during the removal of an aboveground storage tank and/or lines.

(5) All UST's currently being used as AST's must be destroyed upon closure. A certificate of destruction must be included with the AST Closure Report and submitted to PSTD within forty-five (45) days of closure.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 36 Ok Reg 585, eff 8-1-19; Amended at 40 Ok Reg 1797, eff 10-1-23; Amended at 41 Ok Reg 1803, eff 10-1-24]

165:26-2-214. Assessing the site at tank closure or change in service

(a) When permanent closure, a change in service (excluding a change in a regulated substance), or tank or line repair, and/or replacement is completed, the owner or operator must measure for the presence of a release where contamination is most likely to be present at the aboveground storage tank system site. Please refer to the AST Closure Sampling Location Requirements document on PSTD's website.

(b) For tank systems containing petroleum product, analyses may be done for BTEX and TPH (GRO and/or DRO, whichever is applicable), along with total lead if appropriate.

(c) If contaminated soils, contaminated groundwater, or free product as a liquid or vapor is discovered, the owner must immediately begin corrective action in accordance with OAC 165:29 of Commission rules.

(d) All sampling must be conducted under the supervision of a Licensed Environmental Consultant.

(e) The requirements of this Section do not apply to aboveground storage tanks which are located in or on buildings.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 34 Ok Reg 958, eff 9-11-17; Amended at 41 Ok Reg 1803, eff 10-1-24]

165:26-2-215. Requirements for returning to service [RENUMBERED TO 165:26-2-212.1]

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Renumbered to 165:26-2-212.1 at 23 Ok Reg 2297, eff 7-1-06]

SUBCHAPTER 3. RELEASE PREVENTION AND DETECTION REQUIREMENTS

PART 1. RELEASE PROHIBITION, REPORTING AND INVESTIGATION [REVOKED]

165:26-3-1. Release prohibition [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 12 Ok Reg 2057, eff 7-1-95; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-3-2. Release reporting [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 12 Ok Reg 2057, eff 7-1-95; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-3-3. Release, investigation, and confirmation [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 12 Ok Reg 2057, eff 7-1-95; Amended at 15 Ok Reg 3020, eff 7-15-98; Revoked at 17 Ok Reg 2875, eff 7-15-00]

PART 3. RECORDKEEPING [REVOKED]**165:26-3-11. Availability of records [RENUMBERED TO 165:26-1-55]**

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 14 Ok Reg 2515, eff 7-1-97; Amended at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Renumbered to 165:26-1-55 at 23 Ok Reg 2297, eff 7-1-06]

165:26-3-12. Repair records [RENUMBERED TO 165:26-1-56]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 14 Ok Reg 2515, eff 7-1-97; Amended at 17 Ok Reg 2875, eff 7-15-00; Amended at 22 Ok Reg 1752, eff 7-1-05; Renumbered to 165:26-1-56 at 23 Ok Reg 2297, eff 7-1-06]

165:26-3-13. Tank installation, closure and removal records [RENUMBERED TO 165:26-1-57]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 14 Ok Reg 2515, eff 7-1-97; Amended at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Renumbered to 165:26-1-57 at 23 Ok Reg 2297, eff 7-1-06]

165:26-3-14. Release detection and corrosion protection records [RENUMBERED TO 165:26-1-58]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 12 Ok Reg 2057, eff 7-1-95; Amended at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Renumbered to 165:26-1-58 at 23 Ok Reg 2297, eff 7-1-06]

165:26-3-15. Spill and overfill records [RENUMBERED TO 165:26-1-59]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 17 Ok Reg 2875, eff 7-15-00; Renumbered to 165:26-1-59 at 23 Ok Reg 2297, eff 7-1-06]

165:26-3-16. Piping records [RENUMBERED TO 165:26-1-60]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Renumbered to 165:26-1-60 at 23 Ok Reg 2297, eff 7-1-06]

165:26-3-17. Underground line tightness testing [RENUMBERED TO 165:26-1-48]

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Renumbered to 165:26-1-48 at 23 Ok Reg 2297, eff 7-1-06]

165:26-3-18. Inventory records [RENUMBERED TO 165:26-1-61]

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Renumbered to 165:26-1-61 at 23 Ok Reg 2297, eff 7-1-06]

PART 4. RELEASE DETECTION**165:26-3-19. General monitoring requirements**

Tanks must be monitored at least every 30 days for releases using one of the methods or combinations of methods listed in this Chapter.

[Source: Added at 23 Ok Reg 2297, eff 7-1-06]

165:26-3-20. General release detection methods and devices

(a) Owners and operators of new and existing aboveground storage tank systems must use a release detection method, or a combination of release detection methods, that is:

(1) Capable of detecting a release of regulated substances from any portion of the aboveground storage tank system that routinely contains product.

(2) Designed, installed, calibrated, operated, and maintained in accordance with the manufacturer's instructions, including routine maintenance and service checks for operability or running conditions.

(3) Capable of meeting the performance requirements of this Chapter, with any performance claims and their manner of determination described in writing by the equipment manufacturer or installer.

(4) Sampled, tested, or checked for a release at least once every 30 days.

(b) Owners and/or operators must keep all written manufacturer and installer performance specifications and the manner in which those specifications are determined.

(c) All electronic and mechanical equipment used for release detection, monitoring or warning must be tested for proper operation and calibration annually or per the manufacturer's recommendation, whichever is more frequent.

[Source: Added at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08]

165:26-3-20.1. Monitoring requirements for aboveground tanks and aboveground piping

One of the following methods must be used:

(1) Visual Monitoring.

(A) Visual inspection of the aboveground storage tank systems to identify cracks or other defects in the secondary containment area and product transfer area.

(B) Visual inspection of the exterior surface of the tanks, piping, valves, pumps and other equipment for cracks, corrosion, releases and maintenance deficiencies; and identify poor maintenance, operating practices or malfunctioning equipment.

(C) Visual inspection of elevated tanks or tanks on concrete slabs.

(D) Visual inspection of the area between the tank's outer shell or the tank's floor and containment area or a vapor monitoring of the soil directly under the tank bottom or perimeter and the water table, unless the tank containment has a sound concrete floor.

(E) Visual inspections are not adequate where due to the nature of the aboveground storage tank and/or its secondary containment it cannot be determined whether a leak has occurred. A good example would be a vertical tank that is not raised off the ground, making it impossible to visually inspect its bottom, and is not sitting on a sound concrete slab within sound secondary containment.

(F) An annual line tightness test performed by a licensed tester may be used in lieu of thirty (30) day visual monitoring for aboveground product piping.

(2) **Inventory Reconciliation.** Product inventory control (or another test of equivalent performance) must be conducted at least every thirty (30) days to detect a release of at least one percent (1.0%) of flow-through plus 130 gallons on a thirty (30) day basis in the following manner:

(A) Inventory volume measurements for regulated substance inputs, withdrawals, and the amount remaining in the tank are recorded each operating day.

(B) The equipment used is capable of measuring the level of product over the full range of the tank's height to the nearest one-eighth inch (1/8").

(C) The regulated substance inputs are reconciled with delivery receipts by measurement of the tank inventory volume before and after delivery.

(D) Product dispensing is metered and recorded within an accuracy of six (6) cubic inches for every five (5) gallons of product withdrawn.

(E) The measurement of any water level in the bottom of the tank is made to the nearest one-eighth inch (1/8") at least once every thirty (30) days.

(F) Use of the PSTD Inventory Reconciliation Form or an electronic equivalent is required.

(3) **Interstitial Monitoring.** Interstitial monitoring must be used for double walled aboveground storage tank systems. The sampling or testing method must detect a release at least every thirty (30) days in accordance with the manufacturer instructions through the inner wall in any portion of the tank that routinely contains product.

(4) **Automatic tank gauging systems.**

(A) Automatic tank gauging systems (ATGs) that test for the loss of product must conduct an automatic product level monitor test at a minimum frequency of once every thirty (30) days and be capable of detecting at least a 0.2 gallon per hour leak rate with a probability of detection of 0.95 and a probability of false alarm of 0.05.

(B) Automatic tank gauging systems (ATG's) must be third party certified for the size and quantity of the tank. Only third party certifications that have been reviewed and approved by the National Work Group on Leak Detection Evaluations (NWGLDE), as evidenced by their posting on the NWGLDE Web Site, will be accepted (nwgldc.org).

[Source: Amended and renumbered from 165:26-2-134 at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 26 Ok Reg 1831, eff 7-1-09; Amended at 33 Ok Reg 615, eff 8-25-16; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 41 Ok Reg 1803, eff 10-1-24]

165:26-3-20.2. Installation and monitoring requirements for underground piping

Underground piping that routinely contains regulated substances must be installed and

monitored for releases in a manner that meets the following requirements:

(1) **Pressurized piping**

(A) Piping that conveys regulated substances under pressure must be equipped with an automatic line leak detector installed and operated in accordance with this Chapter.

(B) New installations and facilities replacing a piping system must have at least one (1) sump sensor, float or similar mechanical device for each tank system, located at the bottom of the lowest piping gradient sump. The interstitial area of the piping must be open inside the sumps to allow fuel to drain into the sumps in the event that a leak occurs. Sensors must be mounted at the bottom of the sump(s) and accessible for testing.

(C) Underground pressure piping from a master dispenser to a satellite dispenser must be designed and installed so that the satellite piping is tested by the automatic line leak detector. An annual line tightness test performed by a licensed tester is required on the satellite underground piping.

(2) **Suction piping.** New installations and facilities replacing a piping system must have at least one (1) sump sensor, float or similar mechanical device for each tank system, located at the bottom of the lowest piping gradient sump. The interstitial area of the piping must be open inside the sumps to allow fuel to drain into the sumps in the event that a leak occurs. Sensors must be mounted at the bottom of the sump(s) and accessible for testing.

(3) **Methods of release detection for pressurized piping.** Each method of release detection for underground pressurized piping must be performed in accordance with the following requirements:

(A) Automatic mechanical line leak detectors and annual line tightness testing

(i) Methods which alert the owner and/or operator to the presence of a leak by restricting or shutting off the flow of regulated substances through piping or by triggering an audible or visual alarm may be used only if they detect leaks of three (3) gallons per hour at ten (10) psi line pressure within one (1) hour.

(ii) An annual test of the operation of the leak detector must be conducted by a licensed tester by simulating a leak in accordance with the manufacturer's requirements.

(iii) Automatic line leak detectors installed on or after September 22, 1991 must be capable of detecting the leak rate with a probability of detection of 0.95 and a probability of false alarm of 0.05.

(iv) A hydrostatic line tightness test must be performed annually by a licensed tester.

(B) Sump sensors with automatic line leak detectors

(i) Double walled piping with sump sensors, floats or similar mechanical devices at each dispenser, transition and tank sump may be used in lieu of annual line tightness testing except at marinas where a line tightness test is required by April 1st of each year.

(ii) The sump sensors, floats or other mechanical devices used must be tested annually by a licensed tester. This test must be scheduled in the established online format prior to testing. Sensors status and alarm history reports must be printed and retained on an interstitial monitoring form used every thirty (30) days.

(iii) An annual function test of the operation of the leak detector must be conducted by a licensed tester by simulating a leak in accordance with the manufacturer's requirements.

(C) Electronic line leak detection. A certified electronic line leak detector may be used in lieu of a mechanical line leak detector and annual tightness test only if:

(i) The system is capable of detecting and tests for a leak of three (3) gallons per hour before or after each operation of the submersible turbine pump; and

- (ii) The system is capable of detecting and tests for a leak of 0.2 gallons per hour at least once every thirty (30) days; and
 - (iii) The system is capable of detecting and tests for a leak of 0.1 gallons per hour annually; and
 - (iv) The system must be function tested annually by a licensed tester by simulating a leak in accordance with manufacturer's specifications. If the system has printer capabilities, attach the electronic line leak detector printout documenting the system shutdown or alarm when tested.
- (4) **Methods of release detection for suction piping.** Each method of release detection for underground suction piping must be performed in accordance with the following requirements.
- (A) **Sump Sensors**
 - (i) Double walled piping with sump sensors, floats or similar mechanical devices at each dispenser, transition and tank sump may be used in lieu of annual line tightness testing except at marinas where a line tightness test is required by April 1st of each year.
 - (ii) The sump sensors, floats or other mechanical devices used must be tested annually by a licensed tester. This test must be scheduled in the established online format prior to testing. Sensors status and alarm history reports must be printed and retained or an interstitial monitoring form used every thirty (30) days.
 - (B) **Annual Line Tightness Testing.** A hydrostatic line tightness test must be performed annually by a licensed tester.

[Source: Amended and renumbered from 165:26-2-56 at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 41 Ok Reg 1803, eff 10-1-24]

165:26-3-20.3. Commission-approved alternative methods [REVOKED]

[Source: Renumbered from 165:26-2-57 at 23 Ok Reg 2297, eff 7-1-06; Revoked at 25 Ok Reg 2187, eff 7-11-08]

PART 5. SPILL AND OVERFILL PREVENTION REQUIREMENTS [REVOKED]

165:26-3-21. General spill and overfill prevention requirements [AMENDED AND RENUMBERED TO 165:26-2-5.1]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 144, eff 10-6-05 (emergency); Amended and renumbered to 165:26-2-5.1 at 23 Ok Reg 2297, eff 7-1-06]

165:26-3-22. Spill Prevention, Control and Countermeasure Plan [RENUMBERED TO 165:26-2-32.1]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Renumbered to 165:26-2-32.1 at 23 Ok Reg 2297, eff 7-1-06]

PART 7. COMPATIBILITY [REVOKED]

165:26-3-31. Compatibility [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 8. INSTALLATION OF ABOVEGROUND STORAGE TANK SYSTEMS [REVOKED]**165:26-3-53. Aboveground storage tank installation [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-3-54. Licensing procedure for aboveground storage tank installers [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 9. REPAIRS TO ABOVEGROUND STORAGE TANK SYSTEMS [REVOKED]**165:26-3-55. Repairs to aboveground tank systems [REVOKED]**

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 11. REMOVAL AND CLOSURE OF ABOVEGROUND STORAGE TANK SYSTEMS [REVOKED]**165:26-3-61. Compliance with removal and closure requirements [REVOKED]**

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-3-62. Temporary removal from service [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-3-63. Permanent closure [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 14 Ok Reg 2515, eff 7-1-97; Amended at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-3-63.1. Assessing the site at tank closure or change in service [REVOKED]

[Source: Added at 14 Ok Reg 2515, eff 7-1-97; Amended at 15 Ok Reg 3020, eff 7-15-98; Amended at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-3-63.2. Tank removal and closure records [REVOKED]

[Source: Added at 15 Ok Reg 3020, eff 7-15-98; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-3-64. Requirements for returning to service [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 12 Ok Reg 2057, eff 7-1-95; Amended at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 13. CORRECTIVE ACTION REQUIREMENTS [REVOKED]**165:26-3-71. General applicability [REVOKED]**

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 12 Ok Reg 2057, eff 7-1-95; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-3-71.1. Prescribed forms [REVOKED]

[Source: Added at 12 Ok Reg 2057, eff 7-1-95; Amended at 15 Ok Reg 2515, eff 7-1-97; Amended at 15 Ok Reg 3020, eff 7-15-98; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-3-72. Initial response [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-3-73. Initial abatement measures and site check [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 12 Ok Reg 2057, eff 7-1-95; Amended at 14 Ok Reg 2515, eff 7-1-97; Amended at 15 Ok Reg 3020, eff 7-15-98; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-3-73.1. Initial site characterization and corrective action plan [REVOKED]

[Source: Added at 14 Ok Reg 2515, eff 7-1-97; Amended at 15 Ok Reg 3020, eff 7-15-98; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-3-74. Tier 1 and Tier 1A ORBCA [REVOKED]

[Source: Added at 9 Ok Reg 3739, eff 8-27-92; Amended at 12 Ok Reg 2057, eff 7-1-95; Amended at 14 Ok Reg 2515, eff 7-1-97; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-3-74.1. Free product removal [REVOKED]

[Source: Added at 12 Ok Reg 2057, eff 1-7-95; Amended at 14 Ok Reg 2515, eff 7-1-97; Amended at 15 Ok Reg 3020, eff 7-15-98; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-3-74.2. Tier 2 and Tier 3 ORBCA [REVOKED]

[Source: Added at 12 Ok Reg 2057, eff 7-1-95; Amended at 14 Ok Reg 2515, eff 7-1-97; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-3-74.3. Remedial action plan [REVOKED]

[Source: Added at 12 Ok Reg 2057, eff 7-1-95; Amended at 14 Ok Reg 2515, eff 7-1-97; Amended at 15 Ok Reg 3020, eff 7-15-98; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-3-74.4. Closure of a case [REVOKED]

[Source: Added at 12 Ok Reg 2057, eff 7-1-95; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-3-74.5. Public participation [REVOKED]

[Source: Added at 12 Ok Reg 2057, eff 7-1-95; Amended at 14 Ok Reg 2515, eff 7-1-97; Amended at 15 Ok Reg 3020, eff 7-15-98; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-3-75. Laboratory analysis [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 12 Ok Reg 2057, eff 7-1-95; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-3-76. Use of Certified UST Consultants [REVOKED]

[Source: Added at 12 Ok Reg 2057, eff 7-1-95; Revoked at 17 Ok Reg 2875, eff 7-15-00]

PART 14. RELEASE REPORTING REQUIREMENTS**165:26-3-77. Release reporting**

(a) The reporting requirements of this Part do not relieve the owner or operator of the responsibility to take necessary corrective action pursuant to OAC 165:29 to protect the public health, safety and the environment, including the containment and cleanup of spills and overfills that are not required to be reported by this Chapter. No person shall allow a confirmed or suspected release of regulated substances from an aboveground storage tank system to continue without reporting to PSTD or initiating an investigation within twenty-four (24) hours of discovery as required by this Chapter. Owners and operators of aboveground storage tank systems, as well as persons who transport regulated substances must ensure that spills and overfills do not occur.

(b) All aboveground storage tank system owners, operators, their employees or agents, or transporters must report to PSTD within twenty-four (24) hours of discovering any substances, conditions or monitoring results that indicate a release may have occurred using the link provided on the release reporting tab on PSTD's webpage on the Commission website; by email at PSTReleaseReporting@occ.ok.gov; or by telephone at (405) 521-4683 or 1-888-621-5878. If after hours, or on weekends or holidays, call the PSTD emergency phone number at (405) 823-0994. Owners or operators must provide written confirmation to follow within twenty (20) days in

accordance with the requirements established in this Chapter. Events indicating a release include, but are not limited to, the following:

- (1) The discovery of released regulated substances at the aboveground storage tank system facility or in the surrounding area (such as the presence of free product or vapors in soils, basements, crawlspaces, sewer and utility lines, and nearby surface water) whether on-site or off-site.
 - (2) Any unusual operating conditions observed by owners, operators, their employees, or agents such as the unexplained erratic behavior of product dispensing equipment, the sudden loss of product from the aboveground storage tank system, or an unexplained presence of water in the tank, unless system equipment is found to be defective but not leaking, and is immediately repaired or replaced.
 - (3) In the case of inventory control, two (2) consecutive thirty (30) day periods where the Total Gallons Over/Short is greater than the "Leak Check" (one percent (1%) of product sales plus 130 gallons) must be reported to PSTD within twenty-four (24) hours of the owner, operator, their employees, or agents discovering the inventory control results.
 - (4) Monitoring results from a release detection method required by this Chapter that indicate a release may have occurred unless the monitoring device is found to be defective, and is immediately repaired, recalibrated, or replaced, and additional monitoring does not confirm the initial result.
- (c) While aboveground releases of petroleum of less than twenty-five (25) gallons need not be reported to PSTD, they must be recorded by the owner or operator and contained and cleaned up immediately. All of the following releases must be reported to PSTD electronically or by telephone within twenty-four (24) hours of discovery, by the owner, operator, employee, or agent, with a written confirmation to follow within twenty (20) days in accordance with the requirements established in this Chapter:
- (1) All known belowground releases in any quantity; for example, a release resulting from a line broken during an excavation.
 - (2) Any aboveground release of petroleum greater than twenty-five (25) gallons.
 - (3) Any aboveground release of petroleum that is less than twenty-five (25) gallons, but cannot be contained and cleaned up within twenty-four (24) hours.
- (d) All owners and/or operators of aboveground storage tank systems must maintain records of all reportable and non-reportable events listed in this section sufficient to permit adequate inspection and review by PSTD. These records must be kept for three (3) years following the date of the event.
- (e) If any of the possible, probable or definite release conditions set forth in subsections (a) through (c) above are not reported within twenty-four (24) hours, the owner, operator, their employees, or agents may be subject to fines, Formal Enforcement Action and/or shutdown of operations.
- (f) Any releases requiring emergency corrective action must be reported immediately to PSTD at (405) 521-4683 or 1-888-621-5878. After office hours, weekends or holidays, calls must be reported to PSTD's emergency number at (405) 823-0994.

[Source: Renumbered from 165:26-3-191 at 23 Ok Reg 2297, eff 7-1-06; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 33 Ok Reg 615, eff 8-25-16; Amended at 34 Ok Reg 958, eff 9-11-17; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 36 Ok Reg 585, eff 8-1-19; Amended at 37 Ok Reg 1143, eff 10-1-20]

PART 15. REQUIREMENTS FOR CORROSION PROTECTION

SYSTEMS [REVOKED]**165:26-3-80. Corrosion protection [RENUMBERED TO 165:26-2-40]**

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Renumbered to 165:26-2-40 at 23 Ok Reg 2297, eff 7-1-06]

165:26-3-81. Compliance with corrosion protection requirements and manufacturer's specifications [RENUMBERED TO 165:26-2-41]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Renumbered to 165:26-2-41 at 23 Ok Reg 2297, eff 7-1-06]

165:26-3-82. Frequency and criteria of inspections and tests [RENUMBERED TO 165:26-2-42]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Renumbered to 165:26-2-42 at 23 Ok Reg 2297, eff 7-1-06]

165:26-3-83. Impressed current systems [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-3-84. Recordkeeping [REVOKED]

[Source: Added at 9 Ok Reg 3739, eff 8-27-92¹; Revoked at 17 Ok Reg 2875, eff 7-15-00]

EDITOR'S NOTE: ¹The text of this Section was originally published incorrectly at 9 Ok Reg 2719. The text originally published was different from the text approved by the Governor and the Legislature. The correct text was subsequently published at 9 Ok Reg 3739, effective 8-27-92.

165:26-3-85. Qualifications for conducting inspections and tests [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

PART 17. RELEASE INVESTIGATION**165:26-3-171. Release investigation and confirmation**

(a) This Section applies to the investigation of all reportable releases unless PSTD staff specifically waives any part of this Section in writing.

(b) Owners and/or operators must immediately investigate and confirm all suspected releases of regulated substances requiring reporting under this Chapter within 7 days of receipt of notice from PSTD, using the following steps or another procedure approved by PSTD:

(1) **System test.** Owners and/or operators must conduct tightness tests that determine whether a leak exists in the storage tank system.

(A) Owners and/or operators must repair, remove or replace the aboveground storage tank system and begin investigation in accordance with (b)(2) of this Section if the test results for the system, tank, or delivery piping indicate that a leak exists.

(B) Further investigation is not required if the test results for the system, tank, and delivery piping do not indicate that a leak exists and if indicator chemical concentrations detected in soil or water are not the basis for suspecting a release.

(C) Owners and/or operators must conduct a site check as described in (b)(2) of this Section if the test results for the system, tank and delivery piping do not indicate that a leak exists but indicator chemical concentrations detected in soil or water are above action levels cited in (c).

(2) **Site check.** Owners and/or operators must measure for the presence of a release where regulated substances are most likely to be present at the aboveground storage tank system site. In selecting sample types, sample locations, sample depths, and measurement methods, owners and/or operators must consider the nature of the stored substance, the type of initial alarm or cause for suspicion, the type of native soil, the depth of groundwater, and other factors appropriate for identifying the presence and source of the release. Sample locations should be approximately 5 feet (5') from the outside of the AST system in native soil or another location approved by PSTD. Analyses for both BTEX constituents and the appropriate TPH must be obtained in all cases. Site check investigations must be performed by a PSTD Licensed Environmental Consultant.

(A) If the test results for soil and/or groundwater taken outside the excavation zone or the aboveground storage tank system site confirm that a release has occurred, owners and/or operators must begin corrective action in accordance with Chapter 29 of Commission rules.

(B) If the test results for the native soil and/or groundwater or the aboveground storage tank system site do not indicate that a release has occurred, further investigation is not required.

(c) Laboratory analysis of levels of chemical constituent concentrations that may be required to confirm a case are:

(1) Benzene

(A) Native Soils - 0.5 mg/kg

(B) Groundwater - 0.005 mg/l

(2) Toluene

(A) Native Soils - 40.0 mg/kg

(B) Groundwater - 1.0 mg/l

(3) Ethyl Benzene

(A) Native Soils - 15.0 mg/kg

(B) Groundwater - 0.7 mg/l

(4) Xylene

(A) Native Soils - 200.0 mg/kg

(B) Groundwater - 10.0 mg/l

(5) TPH

(A) Native Soils - 50.0 mg/kg

(B) Groundwater - 2.0 mg/l

(C) If BTEX concentrations are below action levels, a TPH concentration of 500 mg/kg in soil may be required to confirm a case at the discretion of PSTD.

(d) Within twenty (20) days after the reporting of a release, the owner and/or operator must submit a report to PSTD summarizing the steps taken under (a) through (c) of this Section and any resulting information or data. If a release is confirmed through performance of the steps taken

under this Section, then the report must be submitted in accordance with a format established by PSTD, after which corrective action may be required under the provisions of Chapter 29 of Commission rules.

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 31 Ok Reg 1010, eff 9-12-14; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 39 Ok Reg 967, eff 10-1-22]

PART 19. RELEASE REPORTING REQUIREMENTS [REVOKED]

165:26-3-191. Release reporting [RENUMBERED TO 165:26-3-77]

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Renumbered to 165:26-3-77 at 23 Ok Reg 2297, eff 7-1-06]

SUBCHAPTER 4. INSPECTIONS, NOTICES OF VIOLATION, FIELD CITATIONS AND FORMAL ENFORCEMENT ACTIONS

PART 1. INSPECTIONS

165:26-4-1. Owner/operator cooperation

- (a) Owners and operators of regulated aboveground storage tank systems must cooperate with inspections, monitoring, sampling and testing requested by or conducted by PSTD.
- (b) Upon request of PSTD, owners and operators must, at all reasonable times:
- (1) Furnish information relating to the owners' or operators' storage tank facilities, the contents of those facilities, and the associated equipment connected to those facilities.
 - (2) Conduct monitoring or testing of storage tank facilities.
 - (3) Permit PSTD to have access to, and to review, inspect, and copy records relating to storage tank facilities.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 36 Ok Reg 586, eff 8-1-19]

165:26-4-2. Authority of the Commission

The Commission has the responsibility and authority at any reasonable time to:

- (1) Enter any storage tank facility or other place where a storage tank system is located within the State.
- (2) Inspect and obtain samples from any facility of any regulated substances stored in the storage tank system.
- (3) Conduct monitoring or testing of the tanks, piping, associated equipment, contents, or the environment at regulated facilities and any location impacted or potentially impacted by a release at a regulated facility.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 22 Ok Reg 1752, eff 7-1-05]

165:26-4-3. Completion of inspections

All inspections, whether done by PSTD or ordered by the PSTD to be conducted by the owner or operator, must be started and completed with reasonable promptness, and the results submitted to PSTD consistent with the provisions of this Chapter.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 25 Ok Reg 2187, eff 7-11-08]

165:26-4-4. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-4-5. Inspection for compliance

(a) All storage tank systems regulated by this Chapter must be physically inspected for compliance with the provisions of this Chapter.

(b) These inspections may include, but not necessarily be limited to:

- (1) Records of installation.
- (2) Records of repair and retrofit operations.
- (3) Review of release containment practices.
- (4) Review of release detection practices.
- (5) Compliance with prior Commission orders to perform corrective action.
- (6) Records of removal and closure.

(c) In addition, PSTD may perform any other inspection, testing, sampling or monitoring which is necessary to ensure compliance with this Chapter and to protect property, human health and safety and the environment.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 36 Ok Reg 586, eff 8-1-19]

165:26-4-6. Exception and Variances [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Revoked at 25 Ok Reg 2187, eff 7-11-08]

PART 3. PENALTIES [REVOKED]**165:26-4-10. Penalties [RENUMBERED TO 165:26-4-21]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Renumbered to 165:26-4-21 at 23 Ok Reg 2297, eff 7-1-06]

**PART 5. NOTICES OF VIOLATION, FIELD CITATIONS,
AND FORMAL ENFORCEMENT ACTIONS****165:26-4-15. Notices of Violation, Field Citations, and Formal Enforcement Actions**

The purpose of this Section is to create a procedure that allows PSTD Fuel Specialists to issue Notices of Violation (NOVs); and for the Manager of Compliance and Inspection to issue Field

Citation(s) or refer to the Commission's Judicial and Legislative Services Division for Formal Enforcement Action for any violation(s) found during Fuel Specialists' onsite inspections of storage tank systems and facilities. The issuance of an NOV or Field Citation will allow petroleum storage tank owners and operators to promptly address and correct the storage tank violation(s) before a Formal Enforcement Action is initiated.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 36 Ok Reg 586, eff 8-1-19]

165:26-4-16. Notices of Violation

(a) When a PSTD Fuel Specialist finds a violation of any statute, rule, requirement, or order of the Commission regarding the regulation of petroleum storage tanks, the Fuel Specialist may issue a Notice of Violation ("NOV").

(1) A Notice of Violation is to alert the tank owner or operator that a violation has been found. The NOV will describe the violation, and advise that further PSTD enforcement action may occur if the violation is not corrected.

(2) At PSTD's discretion, serious violations can be immediately turned over to the Commission's Judicial and Legislative Services Division for Formal Enforcement Action.

(3) The NOV must explain what the offense is and how it can be corrected.

(b) Notices of Violation will state the following information:

(1) A clear description of the violation(s).

(2) A date by which the violation(s) must be corrected.

(3) The name of the Fuel Specialist issuing the NOV, along with a telephone number and address so that the tank owner or operator can ask the Fuel Specialist questions.

(c) NOV(s) are issued to the owner or operator of the storage tank facility. If the owner/operator is not present, NOV(s) can be given to store personnel.

(d) All notifications and/or correspondence will be mailed or electronically submitted to the owner and/or operator.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 36 Ok Reg 587, eff 8-1-19; Amended at 37 Ok Reg 1143, eff 10-1-20]

165:26-4-17. Re-inspection, Field Citation and Formal Enforcement Actions

(a) On or after the date that the violation is to be corrected, a Fuel Specialist will re-inspect the storage tank facility to verify that the violation has been corrected.

(b) If the re-inspection shows that the violation has not been corrected, the Fuel Specialist may:

(1) Refer the violation to the PSTD Compliance and Inspection Manager or the Director's designee who may initiate Formal Enforcement Action or issue a Field Citation; and/or

(2) Shut down the storage tank system pending correction of the problem or a hearing on the issue.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 33 Ok Reg 615, eff 8-25-16; Amended at 36 Ok Reg 587, eff 8-1-19; Amended at 37 Ok Reg 1143, eff 10-1-20]

165:26-4-18. Issuance of a Field Citation and payment of fine or hearing

- (a) The storage tank owner or operator can either pay the amount of the fine as stated in the Field Citation or request a hearing.
- (b) The tank owner or operator will have thirty (30) days from the date the Field Citation was issued to pay the fine.
- (1) A fine may be paid with cash, a money order, check or electronic method approved by the Commission. Any cash payment must be made at the Commission cashier window. All checks must be made payable to the Oklahoma Corporation Commission - Petroleum Storage Tank Division. If sending payment through the mail, a copy of the Field Citation must be sent with the payment to ensure proper credit.
- (2) Payment of the citation within the thirty (30) day time frame will not be considered an agreement or disagreement with the Field Citation.
- (c) If the storage tank owner or operator disagrees with the Field Citation, they may appear at the hearing at the Commission as provided on the Field Citation. If found in violation of PSTD rules at the time the Commission order is issued, the tank owner or operator must pay the amount of the fine, as well as an administrative cost of \$250.00.
- (d) Refusal to comply with an order of the Commission may result in an additional fine being levied after notice and hearing in an amount as allowed by law, and shutdown of the storage tank system for failure to pay fines.
- (e) Failure of a tank owner or operator to appear at the hearing may result in additional enforcement action.
- (f) Any exceptions to the hearing may be made in accordance with OAC 165:5.
- (g) A tank owner or operator is still responsible for following the Commission's rules regarding petroleum storage tanks regardless of paying a fine or correcting a violation.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 32 Ok Reg 794, eff 8-27-15; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 36 Ok Reg 587, eff 8-1-19; Amended at 37 Ok Reg 1143, eff 10-1-20]

PART 7. PENALTIES**165:26-4-21. Penalties**

If the person disagrees with the violation(s) listed in the Formal Enforcement Action, the person may appear at a Commission hearing. If found in violation of PSTD rules at the time a Commission order is issued, the person must pay the amount of the fine, as well as an administrative cost of \$250.00.

[Source: Renumbered from 165:26-4-10 at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 35 Ok Reg 1010, eff 10-1-18; Amended at 36 Ok Reg 587, eff 8-1-19; Amended at 37 Ok Reg 1143, eff 10-1-20; Amended at 39 Ok Reg 968, eff 10-1-22]

SUBCHAPTER 5. REQUIREMENTS FOR EXISTING ABOVEGROUND STORAGE TANKS SYSTEMS [REVOKED]

PART 1. PURPOSE AND DEFINITION [REVOKED]**165:26-5-1. Applicability [REVOKED]**

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-5-2. Tank upgrading requirements [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 13 Ok Reg 2413, eff 7-1-96]

165:26-5-3. Spill and overfill prevention requirements [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 12 Ok Reg 2057, eff 7-1-95; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-5-4. Release detection methods and devices [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

SUBCHAPTER 6. REQUIREMENTS FOR ABOVEGROUND STORAGE TANK SYSTEMS UTILIZED BY AIRPORTS OPEN TO THE PUBLIC**PART 1. GENERAL APPLICATION AND COMPLIANCE PROVISIONS****165:26-6-1. Application**

(a) This Subchapter applies to aboveground storage tank systems for aircraft fuel at airports. A storage tank system consists of a stationary tank and the pipes, pumps and dispensers attached to it. This Chapter does not extend to aircraft fuel servicing vehicles.

(b) Private airstrips are excluded from this Subchapter.

(c) Subchapters 1 General Provisions, 2 General Requirements for AST's, 3 Release Prevention and Detection, and 4 Inspections, Penalties, and Field Citations shall also apply in addition to this Subchapter.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08]

165:26-6-2. Timeframes for registration and compliance with rules

(a) Stationary tanks greater than 110 gallons must be registered with PSTD.

(b) Airport tank systems must come into full compliance with the rules of this Chapter and subchapters before July 1, 2009.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08]

165:26-6-3. Codes and standards

PSTD adopts NFPA 407, which serves as a basis for the standards in this Subchapter. A copy

of NFPA 407 is available for inspection at PSTD during regular business hours.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 25 Ok Reg 2187, eff 7-11-08]

165:26-6-4. Local jurisdiction [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-5. Consultation of Petroleum Storage Tank Division [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

**PART 3. TANK DESIGN, CONSTRUCTION, CAPACITY AND
LOCATION REQUIREMENTS**

165:26-6-9. Approved tanks, tank design [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-10. Maximum capacity for tanks

There is no maximum capacity for storage tanks at airports. Local jurisdictions may have more stringent regulations.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-11. Emergency pressure release venting [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-12. Aboveground storage tank spacing [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-13. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-6-14. Tank distance requirements

- (a) Existing aboveground storage tanks must be at least 100 feet from the edge of the runway;
- (b) Relocated or new tanks must be at least 200 feet from the edge of the runway.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-15. Requirements on fill pipes [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-16. Collision barriers [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-17. Spill and overflow prevention [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-18. Corrosion protection [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 5. SECONDARY CONTAINMENT REQUIREMENTS [REVOKED]**165:26-6-25. Double-walled tanks [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-26. Secondary containment [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 7. EQUIPMENT AND MATERIALS [REVOKED]**165:26-6-30. Aboveground storage tank piping materials [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-31. Electrical equipment [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 9. PIPING REQUIREMENTS**165:26-6-35. Piping protection [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-36. Piping and gravity flow [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-37. Valves on piping [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-38. External piping protection [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-39. Underground piping materials [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 19 Ok Reg 1616, eff 6-13-02; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-40. Aboveground piping at airports

(a) Aboveground product piping must be metal and rated for the system working pressure or at least 125 psi (860 kPa), whichever is greater.

(b) Flanged connections or approved couplings must be provided to avoid the need for cutting and welding where components are serviced or replaced. Gaskets in flanged connections must be of a material and design that resist fire exposure for a time comparable to the flange and bolts.

(c) Piping must be adequately supported.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04]

PART 11. VAULT REQUIREMENTS [REVOKED]**165:26-6-45. Vaults [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 13. VENTING AND VENTING SPECIFICATIONS [REVOKED]**165:26-6-50. Specific requirements for airport aboveground storage tank vent pipes [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-51. Vent piping size [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-52. Vent piping height [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 15. DISPENSER REQUIREMENTS**165:26-6-60. Dispensers [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 19 Ok Reg 1616, eff 6-13-02; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-61. Dispenser hose

- (a) Aircraft fueling hose that is frequently used must be inspected before use each day.
 - (1) The hose must be checked for evidence of blistering, carcass saturation or separation, cuts, nicks or abrasions that expose reinforcement material, and for slippage, misalignment or leaks at couplings.
 - (2) If coupling slippage or leaks are found, the cause of the problem must be determined.
- (b) Defective hoses must be immediately removed from service.
- (c) At least once each month the hose must be thoroughly inspected including:
 - (1) The hose couplings and the hose must be examined for a length approximately 12 in. (305 mm) adjacent to the couplings.
 - (2) Structural weakness must be checked by pressing the hose in the area around its entire circumference for soft spots.
 - (3) Hoses that show evidence of soft spots must be immediately removed from service.
 - (4) The nozzle screens must be examined for rubber particles. The presence of rubber particles indicates possible deterioration of the interior, and the hose must be immediately removed from service.
 - (5) A hose assembly that has been subjected to abuse, such as severe end-pull, flattening or crushing by a vehicle, or sharp bending or kinking, must be immediately removed from service.
 - (6) If inspection shows that a portion of a hose has been damaged, the hose must be immediately replaced. Two lengths of hose must not be coupled together.
 - (7) Before any hose assembly is placed in service, it must be visually inspected for evidence of damage or deterioration.
 - (8) Kinks or short loops in fueling hose must be avoided.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05]

165:26-6-62. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-6-63. Dispenser location at airports

- (a) Fueling hydrants, cabinets and pits must be located at least 50 ft (15.2 m) from any terminal building, hangar, service building, or enclosed passenger concourse (other than loading bridges).
- (b) Pumps must be located at or below ground level.
- (c) Relay pumping is not allowed.
- (d) Pumps installed outside of buildings must be located at least 5 ft. (1.5 m) from any building opening. They must be substantially anchored and protected against physical damage from collision.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

165:26-6-64. Specific requirements for airport dispensers

- (a) The valve that controls the flow of fuel to an aircraft must have a deadman control. The deadman control device must be arranged to accommodate the operational requirements. The fuel flow control valve must be one of the following:
 - (1) The hydrant pit valve.
 - (2) On the hose nozzle for overwing servicing.
- (b) Deadman controls must be designed to preclude defeating their intended purpose.

- (c) The deadman flow control in the nozzle may be used for overwing fueling.
 - (1) Notches or latches in the nozzle handle that could allow the valve to be locked open are prohibited.
 - (2) Each overwing servicing nozzle must have a cable with a plug or clip for bonding to the aircraft.
 - (3) Nozzles for underwing fueling must be designed to be attached securely to the aircraft adapter before the nozzle can be opened. It must not be possible to disengage the nozzle from the aircraft adapter until the nozzle is fully closed.
- (d) Fuel servicing pump mechanisms must be designed and arranged so that failure or seizure does not cause rupture of the pump housing, a tank, or of any component containing fuel. Fuel pressure must be controlled within the stress limits of the hose and plumbing by means of either an in-line pressure controller, a system pressure relief valve, or other suitable means. The working pressure of any system component must equal or exceed any pressure to which it could be subjected.
- (e) Listed or approved dispensing devices must be used.
- (f) Access to dispensing equipment must be controlled by means of mechanical or electronic devices designed to resist tampering and to prevent access or use by unauthorized persons
- (g) Dispensing devices must have a listed or approved emergency shutoff valve, incorporating a fusible link or other thermally actuated device designed to close automatically in case of fire.
 - (1) This valve must also incorporate a shear section that automatically shuts off the flow of fuel due to severe impact.
 - (2) This valve must be rigidly mounted at the base of the dispenser in accordance with the manufacturer's instructions.
 - (3) Dispensing devices or cabinets must be designed so that a proper bond between the aircraft and the fueling equipment can be established.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

PART 17. TANK FILLING PROCEDURES

165:26-6-70. Tank filling operation [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-71. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-6-72. Tightfill connection requirements [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-73. Emergency controls

- (a) Each fuel system must have means for quickly and completely shutting off the flow of fuel in an emergency. This requirement is in addition to the requirement for a deadman control of fuel flow.
- (b) The emergency fuel shutoff system must include shutoff stations located outside of probable spill areas and near the route that normally is used to leave the spill area or to reach the fire

extinguishers provided for the protection of the area.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

PART 19. DISPENSING PROCEDURES

165:26-6-80. Dispensing fuel into aircraft

Aircraft being fueled from a stationary dispenser must be positioned so that aircraft fuel system vents or fuel tank openings are not closer than 25 ft. (8 m) from any terminal building, hangar, service building or enclosed passenger concourse other than a loading walkway. Aircraft being fueled must not be positioned so that the vent or tank openings are within 50 ft. (15 m) of any combustion and ventilation air-intake to any boiler, heater or incinerator room.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

165:26-6-81. Static protection and bonding

- (a) Dispensing devices or cabinets must be designed so that a proper bond between the aircraft and the fueling equipment can be established.
- (b) Conductive hose must be used to prevent electrostatic discharge but not to accomplish required bonding.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

PART 21. MISCELLANEOUS SAFETY PROVISIONS

165:26-6-85. Fencing [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-86. Required signs

Entrances to fueling areas must be posted with signs that state:

- (1) No Smoking.
- (2) Shut engines off.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

165:26-6-87. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-6-88. Fire extinguishers

- (a) Extinguishers specified for protection of fuel servicing operations should be located along the fence, near dispensers or at emergency remote control stations of airport fixed-fuel systems.
- (b) Extinguishers should be located near but not in probable spill areas.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

165:26-6-89. Sources of ignition [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-90. Monitoring requirements [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 23. RECORDKEEPING [REVOKED]**165:26-6-95. Inventory records [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-6-96. Spill prevention control and countermeasure plan [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

SUBCHAPTER 7. REQUIREMENTS FOR NEW ABOVEGROUND STORAGE TANKS SYSTEMS [REVOKED]**PART 1. DESIGN, CONSTRUCTION, AND INSTALLATION [REVOKED]****165:26-7-1. General standards [REVOKED]**

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 15 Ok Reg 3020, eff 7-15-98; Revoked at 17 Ok Reg 2875, eff 17-15-00]

165:26-7-2. Construction and design standards for tank systems [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 17-15-00]

165:26-7-3. Construction and design standards for piping and ancillary equipment [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 15 Ok Reg 3020, eff 7-15-98; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-7-4. Construction and design standards for the control of spillages and releases [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-7-5. Construction and design standards for physical and safety protection [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

PART 3. RELEASE DETECTION [REVOKED]**165:26-7-11. Tanks [REVOKED]**

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-7-12. Piping [REVOKED]

[Source: Amended at 15 Ok Reg 3020, eff 7-15-98; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-7-13. Methods of release detection for piping [REVOKED]

[Source: Amended at 15 Ok Reg 3020, eff 7-15-98; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-7-14. Testing or monitoring for vapors [REVOKED]

[Source: Amended at 15 Ok Reg 3020, eff 7-15-98; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-7-15. Testing and monitoring for liquids on the groundwater [REVOKED]

[Source: Amended at 15 Ok Reg 3020, eff 7-15-98; Revoked at 21 Ok Reg 2079, eff 7-1-04]

SUBCHAPTER 8. REQUIREMENTS FOR ABOVEGROUND STORAGE TANK SYSTEMS UTILIZED BY MARINAS**PART 1. GENERAL APPLICATION AND COMPLIANCE PROVISIONS****165:26-8-1. Application**

(a) This Subchapter applies to the storage, handling and use of regulated substances kept in aboveground storage tanks at marinas.

(b) Subchapters 1 General Provisions, 2 General Requirements for AST's, 3 Release Prevention and Detection, and 4 Inspections, Penalties, and Field Citations shall also apply in addition to this Subchapter.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08]

165:26-8-2. Timeframes for registration and compliance with rules

(a) Tanks that are greater than 110 gallons must be registered with PSTD. The tank and piping system must come in compliance with the rules of this Chapter and Subchapter before July 1, 2009. Compliance may be required sooner for any part of a system which poses a threat to property, people, or to the environment.

(b) All new underground piping at existing facilities must be installed in accordance with 165:26-2-55, "Underground piping materials," and with 165:26-3-20.2, "Installation and monitoring requirements for underground piping."

(c) All dock or pier product piping from the shoreline to the dispensers at new facilities must be

installed according to 165:26-8-40.1 "Over-water piping at marinas" and 165:26-8-40.2 "Installation requirements for over-water piping".

(d) All dock or pier product piping from the shoreline to the dispensers at existing facilities must be upgraded before the deadline date of July 1, 2009 according to 165:26-8-40.1 "Over-water piping at marinas" and 165:26-8-40.2 "Installation requirements for over-water piping".

(e) Temporary tanks may not be used at marinas.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 144, eff 10-6-05 (emergency); Amended at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 36 Ok Reg 588, eff 8-1-19]

165:26-8-2.1. Release detection requirements for marinas

Monitoring requirements, at a minimum, must consist of an annual line tightness test conducted no later than April 1st of each year by a licensed tester.

[Source: Added at 23 Ok Reg 144, eff 10-6-05 (emergency); Added at 23 Ok Reg 2297, eff 7-1-06; Amended at 41 Ok Reg 1803, eff 10-1-24]

165:26-8-3. Codes and standards [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-4. Local jurisdiction [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-5. Consultation of Petroleum Storage Tank Division [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 3. TANK DESIGN, CONSTRUCTION, CAPACITY AND LOCATION REQUIREMENTS

165:26-8-9. Approved tanks, tank design [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-10. Maximum capacity for tanks

Aboveground storage tanks storing gasoline and diesel fuel at an individual site must be limited to a maximum capacity of 12,000 gal. (45,600 L) and an aggregate capacity of 40,000 gal. (152,000 L). Local jurisdictions may have more stringent regulations.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-11. Emergency pressure release [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-12. Aboveground storage tank spacing [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-13. Location of aboveground storage tanks at marinas

- (a) Tanks supplying marinas and pumps not integral with the dispensing device must be onshore.
- (b) All new aboveground storage tanks located at marinas must be located above the flood stage level.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05]

165:26-8-14. Distance to be kept around tanks [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-15. Requirements on fill pipes [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-16. Collision barriers [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-17. Spill and overflow prevention [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-18. Corrosion protection [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 5. SECONDARY CONTAINMENT REQUIREMENTS [REVOKED]

165:26-8-25. Double-walled tanks [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-26. Secondary containment [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 7. EQUIPMENT AND MATERIALS [REVOKED]

165:26-8-30. Aboveground storage tank piping materials [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-31. Electrical equipment [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 9. OVER-WATER PIPING REQUIREMENTS**165:26-8-35. Piping protection [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-36. Piping and gravity flow [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-37. Valves on piping [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-38. External piping protection [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-39. Underground piping materials [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 19 Ok Reg 1616, eff 6-13-02; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-40. Aboveground piping at marinas [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Revoked at 23 Ok Reg 144, eff 10-6-05 (emergency); Revoked at 23 Ok Reg 2297, eff 7-1-06]

165:26-8-40.1. Over-water piping at marinas

- (a) The design, fabrication, assembly, test, and inspection of the piping system from the fuel tank to the fuel dispensers must be in accordance with NFPA 30 and NFPA 30A.
- (b) The piping must be installed according to the manufacturers installation recommendations and instructions.
- (c) Piping must be listed and approved by the manufacturer for aboveground installations.

[Source: Added at 23 Ok Reg 144, eff 10-6-05 (emergency); Added at 23 Ok Reg 2297, eff 7-1-06]

165:26-8-40.2. Installation requirements for over-water piping**(a) Steel piping.**

(1) Piping shall be installed with proper support and strain relief in order to eliminate the physical stress on the piping and piping connections caused by the constant movement of the water and floating dock. Fuel piping and electrical conduit shall be rigidly attached to the dock before the piping enters the sump area, in order to prevent strain on the entry boots and primary pipe fittings.

(2) Steel flex connectors must be used between the shore piping and the piping on the floating structure and between separate sections of the floating structure to allow for movement of the dock and changes in water levels.

(3) Onshore piping must be rigidly anchored in place to prevent movement when water levels are elevated.

(4) A listed emergency breakaway device designed to retain liquid on both sides of the breakaway point must be installed on each line serving the dock. The breakaway device shall be located where the dock piping will separate from the shore or secured ramp piping. The piping shall be secured at both ends of the breakaway device so that the piping will withstand the forces and pressures exerted upon it.

(5) There must be a normally closed explosion proof solenoid valve with built-in pressure relief or a normally closed explosion proof solenoid valve and a pressure relief valve installed in each product line at the shoreline.

(6) A ball valve must be installed at the shoreline in order to manually shut off the flow of fuel.

(7) Containment sumps must be installed under all dispensers and monitored with sensors. If a pressure system is used all sump sensors must automatically control the electricity to both the solenoid valves and submerged pump. If a suction system is used the sump sensors should automatically control the electricity to both the solenoid valve and suction pump motor.

(8) If the onshore piping is double walled a transition sump is required at the shoreline in order to contain a release from the onshore piping. The transition sump must contain the ball valve and solenoid valve and be rigidly anchored in place.

(b) Double walled piping.

(1) Double walled piping must be installed according to the double wall piping manufacturer recommendations.

(2) All double walled piping installed above the water shall be enclosed inside a rigid metal chase or conduit except at joints requiring flexibility. A flexible metal conduit can be used between shore piping and piping on the floating structure or between separate sections of the floating structure to allow for movement of the dock and changes in water levels. Both the rigid and flexible metal chase/conduit must shield the fuel pipe from damage by fire and in itself be fire resistant.

(3) Due to the constant movement of the water and the floating dock, piping shall be installed with proper support and strain relief in order to eliminate the physical stress on the piping and piping connections. Fuel piping and electrical conduit shall be rigidly attached to the dock before the piping enters the sump area, in order to prevent strain on the entry boots and primary pipe fittings.

(4) Onshore piping must be rigidly anchored in place to prevent movement when water levels are elevated.

(5) A listed emergency breakaway device designed to retain liquid on both sides of the breakaway point must be installed on each line serving the dock. The breakaway device shall

be located where the dock piping will separate from the shore or secured ramp piping. The piping shall be secured at both ends of the breakaway device so that the piping will withstand the forces and pressures exerted upon it.

(6) There must be a normally closed explosion proof solenoid valve with built-in pressure relief or a normally closed explosion proof solenoid valve and a pressure relief valve installed in each product line at the shoreline.

(7) A ball valve must be installed at the shoreline in order to manually shut off the flow of fuel. It must be installed so that it is accessible to the operator at all water levels.

(8) Containment sumps must be installed under all dispensers and monitored with sensors. If a pressure system is used all sump sensors must automatically control the electricity to both the solenoid valves and submerged pump. If a suction system is used the sump sensors should automatically control the electricity to both the solenoid valve and suction pump motor.

(9) A transition sump must be rigidly anchored in place either on the dock or at the shoreline. The transition sump must contain the ball valve, solenoid valve, and emergency breakaway device. The transition sump must be either monitored with a sensor or a bypass tube must be used in order to divert a leak from the transition sump to the dispenser sump where it would be detected by a sensor.

[Source: Added at 23 Ok Reg 144, eff 10-6-05 (emergency); Added at 23 Ok Reg 2297, eff 7-1-06; Amended at 34 Ok Reg 958, eff 9-11-17]

165:26-8-41. Installation and monitoring requirements for piping [REVOKED]

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Revoked at 23 Ok Reg 144, eff 10-6-05 (emergency); Revoked at 23 Ok Reg 2297, eff 7-1-06]

PART 11. VAULT REQUIREMENTS [REVOKED]

165:26-8-45. Vaults [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-50. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

PART 13. VENTING AND VENTING SPECIFICATIONS [REVOKED]

165:26-8-51. Vent piping size [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-52. Vent piping height [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 15. DISPENSER REQUIREMENTS

165:26-8-60. Dispensers [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-61. Dispenser hose

Listed hose assemblies must be used to dispense fuel. Where hose length exceeds 18 ft (5.5m), the hose shall be secured so as to protect it from damage, such as a hose reel, and in no case shall the hose exceed 50 ft (15m) in length.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 23 Ok Reg 144, eff 10-6-05 (emergency); Amended at 23 Ok Reg 2297, eff 7-1-06]

165:26-8-62. Nozzles

Dispensing nozzles used at marinas must be the automatic closing type. Hold-open latch devices from nozzles for marina service are not allowed.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 144, eff 10-6-05 (emergency); Amended at 23 Ok Reg 2297, eff 7-1-06; Amended at 37 Ok Reg 1143, eff 10-1-20]

165:26-8-63. Dispenser location at marinas

Dispensing devices at marinas may be located on open piers, wharves, floating docks, shores or on piers of the solid-fill type, but must be located apart from other structures to provide room for safe ingress and egress of watercraft for fueling. Dispensing devices must be in all cases at least 20 ft. (6 m) from any activity involving fixed sources of ignition.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 22 Ok Reg 1752, eff 7-1-05]

165:26-8-64. Specific requirements for dispensers at marinas; maintenance

When maintenance of a Class I dispenser is necessary the following precautions must be taken before maintenance begins:

- (1) Only persons knowledgeable in performing the required maintenance can perform the work.
- (2) All electrical power to the dispenser, the dispensing pump, and all associated circuits must be shut off at the main electrical panel.
- (3) The emergency shutoff valve at the dispenser, if installed, must be closed.
- (4) All unauthorized persons are prohibited from coming within 20 ft (6 m) of the dispenser while the maintenance work is being done.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

PART 17. TANK FILLING PROCEDURES [REVOKED]**165:26-8-70. Tank filling operation [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-71. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-8-72. Tightfill connection requirements [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-73. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

PART 19. DISPENSING PROCEDURES**165:26-8-80. Attendants at marinas**

(a) Marinas may have an attendant or supervisor on duty when the marina is open for business. The attendant's primary function will be to supervise, observe, and control the dispensing of fuels to insure that all safety requirements are met, and to insure that the waters of the state are not contaminated by fuel.

(b) At unattended marine facilities an emergency shut off device must be installed to meet the following requirements:

- (1) Installed between 20 to 100 feet from the fuel dispensing devices that they serve.
- (2) Device must shut down the fuel dispensing system in the event of an emergency.
- (3) Must be readily accessible to patrons.
- (4) Emergency instructions must be conspicuously posted.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 144, eff 10-6-05 (emergency); Amended at 23 Ok Reg 2297, eff 7-1-06]

165:26-8-81. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

PART 21. MISCELLANEOUS SAFETY PROVISIONS**165:26-8-85. Fencing [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-86. Required signs

All marinas must have a sign printed in ¼ to ½ inch text in black or red block capital letters on a white background conspicuously posted and easily readable from the dispensing area which says:

- (1) BEFORE FUELING:
 - (A) Stop all engines and auxiliaries.
 - (B) Shut off all electricity, open flames and heat sources.
 - (C) Check all bilges for fuel vapors.

- (D) Extinguish all smoking materials.
- (E) Close access fittings and openings to prevent fuel vapors from entering enclosed spaces of the vessel.
- (2) DURING FUELING:
 - (A) Maintain nozzle contact with the fill pipe.
 - (B) Wipe up spills immediately.
 - (C) Avoid overfilling.
 - (D) Fuel filling nozzle must be attended at all times.
- (3) AFTER FUELING:
 - (A) Inspect bilges for leakage and fuel odors.
 - (B) Ventilate until odors are gone.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 144, eff 10-6-05 (emergency); Amended at 23 Ok Reg 2297, eff 7-1-06]

165:26-8-87. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-8-88. Fire extinguishers

- (a) Each marina must have a 40B:C fire extinguisher.
- (b) A minimum of three (3) extinguishers must be located at the fuel dock and one or more located so they will be within fifty feet (50') or fifteen meters (15 m) of each pump, dispenser, and underground fill pipe opening.
- (c) Piers which extend more than five hundred feet (500') or one hundred fifty-two meters (152 m) in travel distance from shore must have a Class III standpipe installed in accordance with NFPA 14, Standard for the Installation of Standpipe and Hose Systems.
- (d) There must be a knife at the fuel dock for quickly cutting mooring lines in an emergency and a push pole for shoving away a boat.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 144, eff 10-6-05 (emergency); Amended at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 36 Ok Reg 588, eff 8-1-19]

165:26-8-89. Sources of ignition [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-90. Monitoring requirements [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 23. RECORDKEEPING [REVOKED]

165:26-8-95. Inventory records [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-8-96. Spill Prevention Control and Countermeasure Plan [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

SUBCHAPTER 9. INSPECTIONS, FEES AND PENALTIES [REVOKED]**PART 1. INSPECTIONS [REVOKED]****165:26-9-1. Owner/operator cooperation [REVOKED]**

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-9-2. Authority of the Commission [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-9-3. Completion of inspections [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-9-4. Recordkeeping [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-9-5. Inspection for compliance [REVOKED]

Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

PART 3. FEES [REVOKED]**165:26-9-11. Fees [REVOKED]**

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

PART 5. PENALTIES [REVOKED]**165:26-9-21. Penalties [REVOKED]**

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

PART 7. FIELD CITATION [REVOKED]**165:26-9-25. Field citations [REVOKED]**

[Source: Added at 14 Ok Reg 2515, eff 7-1-97; Amended at 15 Ok Reg 3020, eff 7-15-98; Revoked at 17 Ok Reg 2875, eff 7-15-00]

SUBCHAPTER 10. REQUIREMENTS FOR ABOVEGROUND STORAGE TANK SYSTEMS UTILIZED BY RETAIL FACILITIES

PART 1. GENERAL APPLICATION AND COMPLIANCE PROVISIONS

165:26-10-1. Application

(a) This Subchapter applies to the storage, handling and use of all regulated substances which are kept in aboveground storage tanks, at facilities which engage in the retail sale of a Regulated Substance.

(b) Subchapters 1 General Provisions, 2 General Requirements for AST's, 3 Release Prevention and Detection, and 4 Inspections, Penalties, and Field Citations shall also apply in addition to this Subchapter.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 26 Ok Reg 1831, eff 7-1-09]

165:26-10-2. Timeframes for registration and compliance with rules

(a) Tanks at retail facilities that are greater than 110 gallons must be registered with PSTD.

(b) Temporary tanks may not be used at retail facilities.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 2297, eff 7-1-06; Amended at 24 Ok Reg 1479, eff 7-1-07; Amended at 25 Ok Reg 2187, eff 7-11-08]

165:26-10-3. Codes and standards [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-4. Local jurisdiction [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-5. Consultation of Petroleum Storage Tank Division [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 3. TANK DESIGN, CONSTRUCTION, CAPACITY AND LOCATION REQUIREMENTS

165:26-10-9. Approved tanks, tank design [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-10. Maximum capacity for tanks

Aboveground storage tanks storing Class I and Class II liquids at an individual site must be

limited to a maximum capacity of 12,000 gal. (45,600 L) and an aggregate capacity of 40,000 gal. (152,000 L). Other authorities having jurisdiction may have more stringent regulations.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-11. Emergency pressure release [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-12. Aboveground storage tank spacing [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-13. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-10-14. Distance to be kept around tanks [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-15. Requirements on fill pipes [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-16. Collision barriers [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-17. Spill and overflow prevention [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-18. Corrosion protection [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 5. SECONDARY CONTAINMENT REQUIREMENTS [REVOKED]

165:26-10-25. Double-walled tanks [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-26. Secondary containment [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 7. EQUIPMENT AND MATERIALS [REVOKED]**165:26-10-30. Aboveground storage tank piping materials [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-31. Electrical equipment [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 9. PIPING REQUIREMENTS [REVOKED]**165:26-10-35. Piping protection [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-36. Piping and gravity flow [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-37. Valves on piping [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-38. External piping protection [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-39. Underground piping materials [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 19 Ok Reg 1616, eff 6-13-02; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-40. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

PART 11. VAULT REQUIREMENTS [REVOKED]**165:26-10-45. Vaults [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 13. VENTING AND VENTING SPECIFICATIONS [REVOKED]**165:26-10-50. [RESERVED]**

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-10-51. Vent piping size [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-52. Vent piping height [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 15. DISPENSER REQUIREMENTS [REVOKED]

165:26-10-60. Dispensers [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-61. Dispenser hose [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-62. Nozzles [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-63. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-10-64. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

PART 17. TANK FILLING PROCEDURES [REVOKED]

165:26-10-70. Tank filling operation [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-71. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-10-72. Tightfill connection requirements [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-73. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

PART 19. [RESERVED]**PART 21. MISCELLANEOUS SAFETY PROVISIONS [REVOKED]****165:26-10-85. Fencing [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-86. Required signs [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-87. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-10-88. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-10-89. Sources of ignition [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-90. Monitoring requirements [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 23. RECORDKEEPING [REVOKED]**165:26-10-95. Inventory records [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-10-96. Spill Prevention Control and Countermeasure Plan [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

SUBCHAPTER 11. ADMINISTRATIVE PROVISIONS [REVOKED]**165:26-11-1. Hearings, orders and appeals [REVOKED]**

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-11-2. Changes to rules [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-11-3. Notices [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Amended at 12 Ok Reg 2057, eff 7-1-95; Revoked at 17 Ok Reg 2875, eff 7-15-00]

165:26-11-4. Severability [REVOKED]

[Source: Added at 9 Ok Reg 2719, eff 7-13-92; Revoked at 17 Ok Reg 2875, eff 7-15-00]

SUBCHAPTER 12. REQUIREMENTS FOR ABOVEGROUND STORAGE TANK SYSTEMS UTILIZED AT FLEET AND COMMERCIAL FACILITIES

PART 1. GENERAL APPLICATION AND COMPLIANCE PROVISIONS

165:26-12-1. Application

(a) This Subchapter applies to the storage, handling and use of regulated substances at fleet and commercial facilities which are kept in aboveground storage tanks, with an individual capacity of 2,100 gallons or more. Aboveground storage tanks with an individual capacity of less than 2,100 gallons are not subject to PSTD regulation, and may not access the Indemnity Fund in the event of a release from such aboveground storage tanks. Although PSTD does not regulate aboveground storage tanks with an individual capacity of less than 2,100 gallons, owners of such tanks should be aware they may be subject to regulation by other jurisdictions.

(b) Subchapters 1 General Provisions, 2 General Requirements for AST's, 3 Release Prevention and Detection, and 4 Inspections, Penalties, and Field Citations shall also apply in addition to this Subchapter.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 24 Ok Reg 1479, eff 7-1-07; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 41 Ok Reg 1803, eff 10-1-24]

165:26-12-2. Timeframes for registration and compliance with rules

(a) Tanks at fleet or commercial facilities with a capacity of 2,100 gallons or greater must be registered with PSTD.

(b) Temporary tanks may not be used at fleet and commercial facilities.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 19 Ok Reg 1616, eff 6-13-02; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 2297, eff 7-1-06; Amended at 24 Ok Reg 1479, eff 7-1-07; Amended at 25 Ok Reg 2187, eff 7-11-08]

165:26-12-3. Codes and standards [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-4. Local jurisdiction [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-5. Consultation of Petroleum Storage Tank Division [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 3. TANK DESIGN, CONSTRUCTION, CAPACITY AND LOCATION REQUIREMENTS

165:26-12-9. Approved tanks, tank design [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-10. Maximum capacity for tanks

Aboveground storage tanks storing Class I and Class II liquids at a fleet or commercial facility must be limited to a maximum capacity of 20,000 gal. (76,000 L) and an aggregate capacity of 80,000 gal. (304,000 L). Local jurisdictions may have more stringent regulations.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-11. Emergency pressure release [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-12. Aboveground storage tank spacing [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-13. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-12-14. Tank distance requirements

No minimum distance is required between the tanks and the dispenser. Local jurisdictions may have more stringent regulations.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-15. Requirements on fill pipes [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-16. Collision barriers [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-17. Spill and overflow prevention [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-18. Corrosion protection [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 5. SECONDARY CONTAINMENT REQUIREMENTS [REVOKED]**165:26-12-25. Double-walled tanks [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-26. Secondary containment [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 7. EQUIPMENT AND MATERIALS [REVOKED]**165:26-12-30. Aboveground storage tank piping materials [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-31. Electrical equipment [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 9. PIPING REQUIREMENTS [REVOKED]**165:26-12-35. Piping protection [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-36. Piping and gravity flow [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-37. Valves on piping [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-38. External piping protection [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-39. Underground piping materials [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 19 Ok Reg 1616, eff 6-13-02; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-40. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

PART 11. VAULT REQUIREMENTS [REVOKED]**165:26-12-45. Vaults [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 13. VENTING AND VENTING SPECIFICATIONS [REVOKED]**165:26-12-50. [RESERVED]**

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-12-51. Vent piping size [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-52. Vent piping height [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 15. DISPENSER REQUIREMENTS [REVOKED]**165:26-12-60. Dispensers [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-61. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-12-62. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-12-63. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-12-64. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

PART 17. TANK FILLING PROCEDURES [REVOKED]

165:26-12-70. Tank filling operation [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-71. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-12-72. Tightfill connection requirements [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-73. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

PART 19. [RESERVED]

PART 21. MISCELLANEOUS SAFETY PROVISIONS [REVOKED]

165:26-12-85. Fencing [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-86. Required signs [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-87. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-12-88. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-12-89. Sources of ignition [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-90. Monitoring requirements [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 23. RECORDKEEPING [REVOKED]

165:26-12-95. Inventory records [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-12-96. Spill Prevention Control and Countermeasure Plan [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

**SUBCHAPTER 14. REQUIREMENTS FOR ABOVEGROUND STORAGE
TANK SYSTEMS UTILIZED BY BULK PLANT FACILITIES**

PART 1. GENERAL APPLICATION AND COMPLIANCE PROVISIONS

165:26-14-1. Application

(a) This Subchapter applies to the storage, handling and use of regulated substances at bulk plant facilities which are kept in aboveground storage tanks. Bulk plants built after July 15, 2000 must comply with this Chapter and Subchapter.

(b) Bulk plants, already in existence on July 15, 2000 will not be required to comply with these rules unless they pose a threat to property, people or the environment. If a safety or environmental threat does exist at a bulk plant, the owner will be required to correct the specific problem.

(c) Subchapters 1 General Provisions, 2 General Requirements for AST's, 3 Release Prevention and Detection, and 4 Inspections, Penalties, and Field Citations shall also apply in addition to this Subchapter.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 25 Ok Reg 2187, eff 7-11-08]

165:26-14-2. Timeframes for registration and compliance with rules

(a) Tanks at bulk plants must be registered with PSTD. The tanks must come in compliance with the rules of this Subchapter before July 15, 2010. Compliance may be required sooner for any part of an existing bulk plant that poses a threat to property, people or the environment.

(b) Temporary tanks will not be allowed at bulk plant facilities.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08]

165:26-14-3. Codes and standards [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-4. Local jurisdiction [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-5. Consultation of Petroleum Storage Tank Division [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 3. TANK DESIGN, CONSTRUCTION, CAPACITY AND LOCATION REQUIREMENTS

165:26-14-9. Approved tanks, tank design [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-10. Maximum capacity for tanks

There is no maximum capacity restriction on bulk plants. Local jurisdictions may have more stringent regulations.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-11. Emergency pressure release [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-12. Aboveground storage tank spacing [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-13. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-14-14. Distance to be kept around tanks [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-15. Requirements on fill pipes [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-16. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-14-17. Spill and overflow prevention [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-18. Corrosion protection [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 5. SECONDARY CONTAINMENT REQUIREMENTS [REVOKED]**165:26-14-25. Double-walled tanks [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-26. Secondary containment [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 7. EQUIPMENT AND MATERIALS [REVOKED]**165:26-14-30. Aboveground storage tank piping materials [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-31. Electrical equipment [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 9. PIPING REQUIREMENTS [REVOKED]**165:26-14-35. Piping protection [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-36. Piping and gravity flow [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-37. Valves on piping [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-38. External piping protection [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-39. Underground piping materials [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 19 Ok Reg 1616, eff 6-13-02; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-40. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

PART 11. VAULT REQUIREMENTS**165:26-14-45. Vaults [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 13. VENTING AND VENTING SPECIFICATIONS [REVOKED]**165:26-14-50. [RESERVED]**

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-14-51. Vent piping size [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-52. Vent piping height [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 15. DISPENSER REQUIREMENTS**165:26-14-60. Dispensers**

Bulk plants which have, in addition to their distribution business, a facility for dispensing fuel directly into the fuel tanks of automobiles and trucks must comply with the dispenser requirements of retail facilities.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-61. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-14-62. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-14-63. Location of loading facilities

Tank vehicle and tank car loading and unloading facilities must be separated from aboveground tanks, warehouses, other plant buildings or the nearest line of adjoining property that can be built upon by a distance of at least 25 ft (7.6 m) for Class I liquids and at least 15 ft (4.6 m) for Class II and Class III liquids, measured from the nearest fill spout or transfer connection.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

165:26-14-64. Specific requirements for loading facilities

- (a) Loading and unloading facilities must be provided with drainage systems or other means to contain spills.
- (b) A loading or unloading facility that has a canopy or roof that does not limit the dissipation of heat or dispersion of flammable vapors and does not restrict fire-fighting access and control will be treated as an outdoor facility.
- (c) Loading and unloading facilities at bulk plants that are used to load motor fuel into tank vehicles through open domes must be provided with a means for electrically bonding to protect against static electricity hazards.
 - (1) It must consist of a metal wire that is permanently and electrically connected to the bulk plants fill pipe assembly or to some part of the bulk plants rack structure that is in electrical contact with the fill pipe assembly.
 - (2) The free end of this wire must have a clamp for convenient attachment to some metallic part of the vehicle that is in electrical contact with the cargo tank of the tank vehicle.
 - (3) All parts of the fill pipe assembly, including the drop tube, must form a continuous electrically conductive path.
- (d) Bulk plants where motor fuel or blending materials are loaded or unloaded through open domes of railroad tank cars must be protected against stray electrical current by permanently bonding the bulk plant's fill pipe and the individual storage tanks to at least one rail of the railroad.
- (e) Equipment such as piping, pumps, and meters used for the transfer of Class I liquids between storage tanks and the fill stem of the loading facility cannot be used for the transfer of Class II or Class III liquids.
 - (1) This provision does not apply to water-miscible liquid mixtures where the class of the mixture is determined by the concentration of liquid in water.
 - (2) This provision does not apply where the equipment is cleaned between transfers.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

PART 17. TANK FILLING PROCEDURES

165:26-14-70. Tank filling operation

A delivery vehicle must be separated from any aboveground tank to which it is delivering fuel by at least 25 ft. (7.6 m) if possible.

- (1) No minimum separation distance is required for storage tanks that are filled by gravity.
- (2) The required minimum separation distance will be reduced to 15 ft. (4.6 m) where the fuel being delivered is not a Class I liquid.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

165:26-14-71. Switch loading

To prevent hazards due to a change in flash point of liquids, no tank or tank vehicle that has previously contained a Class I liquid may be loaded with a Class II or Class III liquid unless proper precautions are taken.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

165:26-14-72. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-14-73. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

PART 19. DISPENSING PROCEDURES

165:26-14-80. Dispensing fuel into tank vehicles

Tank vehicles must be loaded and unloaded as follows:

(1) Liquids can only be loaded into cargo tanks whose material of construction is compatible with the chemical characteristics of the liquid.

(2) The liquid being loaded must also be chemically compatible with the liquid hauled on the previous load unless the cargo tank has been cleaned.

(3) When transferring Class I liquids, engines of tank vehicles or motors of auxiliary or portable pumps must be shut down while making and breaking hose connections.

(4) If loading or unloading is done without requiring the use of the motor of the tank vehicle, the vehicle's motor must be shut down throughout any transfer operations involving Class I liquids.

(5) Filling through open domes into the tanks of tank vehicles must be by means of a downspout that extends to within 6 in. of the bottom of the tank.

(6) When top loading a tank vehicle with Class I or Class II liquids without a vapor control system, valves used for the final control of flow must be of the self-closing type and must be manually held open except where automatic means are provided for shutting off the flow when the vehicle is full.

(A) Automatic shutoff systems must be provided with a manual shutoff valve located at a safe distance from the loading nozzle to stop the flow if the automatic system fails.

(B) When bottom loading a tank vehicle, a positive means must be provided for loading a predetermined quantity of liquid, together with a secondary automatic shutoff control to prevent overflow.

(C) The connecting components between the loading rack and the tank vehicle that are required to operate the secondary control must be functionally compatible.

(D) The connection between the liquid loading hose or pipe and the truck piping must be by a dry disconnect coupling.

(7) When bottom loading a tank vehicle that is equipped for vapor control, but when vapor control is not used, the tank must be vented to the atmosphere, at a height not lower than the top of the cargo tank of the vehicle, to prevent pressurization of the tank. Connections to the facility's vapor control system must be designed to prevent the escape of vapor into the atmosphere when not connected to a tank vehicle.

(8) When bottom loading is used, reduced flow rates (until the fill opening is submerged), splash deflectors or other devices must be used to prevent splashing and to minimize turbulence.

(9) To allow for the relaxation of charge, metal or conductive objects, such as gauge tapes, sample containers and thermometers must not be lowered into a compartment while the compartment is being filled or immediately after pumping stops.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

165:26-14-81. Static protection and bonding

Before loading tank vehicles through open domes, a bonding connection must be made to the vehicle or tank before dome covers are raised and must remain in place until filling is completed and all dome covers have been closed and secured.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

PART 21. MISCELLANEOUS SAFETY PROVISIONS

165:26-14-85. Fencing [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-86. Required signs

(a) Conspicuous and legible signs prohibiting smoking must be posted within sight of the customer being served.

(b) Warning signs must be conspicuously posted in the dispensing area incorporating the following or equivalent wording:

(1) WARNING: It is unlawful and dangerous to dispense gasoline into unapproved containers.

(2) NO SMOKING.

(3) STOP MOTOR.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

165:26-14-87. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-14-88. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-14-89. Sources of ignition [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-90. Monitoring requirements [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 23. RECORDKEEPING [REVOKED]**165:26-14-95. Inventory records [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-14-96. Spill Prevention Control and Countermeasure Plan [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

SUBCHAPTER 16. REQUIREMENTS FOR ABOVEGROUND STORAGE TANK SYSTEMS UTILIZED BY EMERGENCY GENERATORS**PART 1. GENERAL APPLICATION AND COMPLIANCE PROVISIONS****165:26-16-1. Application [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 31 Ok Reg 1010, eff 9-12-14; Revoked at 33 Ok Reg 615, eff 8-25-16]

165:26-16-2. Timeframes for registration and compliance with rules [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Amended at 23 Ok Reg 2297, eff 7-1-06; Amended at 25 Ok Reg 2187, eff 7-11-08; Amended at 31 Ok Reg 1010, eff 9-12-14; Revoked at 33 Ok Reg 615, eff 8-25-16]

165:26-16-3. Codes and standards [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-4. Local jurisdiction [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-5. Consultation of Petroleum Storage Tank Division [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 3. TANK DESIGN, CONSTRUCTION, CAPACITY AND LOCATION REQUIREMENTS [REVOKED]**165:26-16-9. Approved tanks, tank design [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-10. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-16-11. Emergency pressure release [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-12. Aboveground storage tank spacing [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-13. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-16-14. Distance to be kept around tanks [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-15. Requirements on fill pipes [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-16. Collision barriers [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-17. Spill and overfill prevention [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-18. Corrosion protection [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 5. SECONDARY CONTAINMENT REQUIREMENTS [REVOKED]**165:26-16-25. Double-walled tanks [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-26. Secondary containment [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 7. EQUIPMENT AND MATERIALS [REVOKED]**165:26-16-30. Aboveground storage tank piping materials [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-31. Electrical equipment [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 9. PIPING REQUIREMENTS [REVOKED]**165:26-16-35. Piping protection [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-36. Piping and gravity flow [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-37. Valves on piping [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-38. External piping protection [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-39. Underground piping materials [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Amended at 19 Ok Reg 1616, eff 6-13-02; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-40. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

PART 11. VAULT REQUIREMENTS [REVOKED]**165:26-16-45. Vaults [REVOKED]**

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 13. VENTING AND VENTING SPECIFICATIONS [REVOKED]**165:26-16-50. [RESERVED]**

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-16-51. Vent piping size [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-52. Vent piping height [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 15. [RESERVED]

PART 17. TANK FILLING PROCEDURES [REVOKED]

165:26-16-70. Tank filling operation [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-71. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-16-72. Tightfill connection requirements [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-73. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

PART 19. [RESERVED]

PART 21. MISCELLANEOUS SAFETY PROVISIONS [REVOKED]

165:26-16-85. Fencing [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-86. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-16-87. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-16-88. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-16-89. Sources of ignition [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

165:26-16-90. Monitoring requirements [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

PART 23. RECORDKEEPING [REVOKED]

165:26-16-95. [RESERVED]

[Source: Reserved at 17 Ok Reg 2875, eff 7-15-00]

165:26-16-96. Spill Prevention Control and Countermeasure Plan [REVOKED]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked at 21 Ok Reg 2079, eff 7-1-04]

SUBCHAPTER 18. FINANCIAL RESPONSIBILITY [REVOKED]

165:26-18-1. Applicability [RENUMBERED TO 165:26-1-36]

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Renumbered to 165:26-1-36 at 23 Ok Reg 2297, eff 7-1-06]

165:26-18-3. Evidence of financial responsibility [RENUMBERED TO 165:26-1-37]

[Source: Added at 21 Ok Reg 2079, eff 7-1-04; Amended at 22 Ok Reg 1752, eff 7-1-05; Renumbered to 165:26-1-37 at 23 Ok Reg 2297, eff 7-1-06]

APPENDIX A. SOIL AND GROUNDWATER REMEDIATION INDEX [REVOKED]

[Source: Added at 12 Ok Reg 2057, eff 7-1-95; Revoked at 14 Ok Reg 2515, eff 7-1-97]

APPENDIX B. SOIL CLEANUP LEVELS [REVOKED]

[Source: Added at 12 Ok Reg 2057, eff 7-1-95; Revoked at 14 Ok Reg 2515, eff 7-1-97]

APPENDIX C. MEAN ANNUAL PRECIPITATION [REVOKED]

[Source: Added at 12 Ok Reg 2057, eff 7-1-95; Revoked at 14 Ok Reg 2515, eff 7-1-97]

APPENDIX D. HYDROLOGICALLY SENSITIVE AREAS [REVOKED]

[Source: Added at 12 Ok Reg 2057, eff 7-1-95; Revoked at 14 Ok Reg 2515, eff 7-1-97]

APPENDIX E. PRIORITIZATION INDEX [REVOKED]

[Source: Added at 14 Ok Reg 2515, eff 7-1-97; Revoked at 17 Ok Reg 2875, eff 7-15-00]

APPENDIX F. FIELD CITATION FINES [REVOKED]

[Source: Added at 14 Ok Reg 2515, eff 7-1-97; Revoked and reenacted at 15 Ok Reg 3020, eff 7-15-98; Revoked at 17 Ok Reg 2875, eff 7-15-00]

APPENDIX G. FIELD CITATIONS TABLE

*Field Citations Table fine amounts will be used when Field Citations are issued, and may be used as a suggested fine amount in a Formal Enforcement Action, but not to exceed the statutorily set limitations in 17 O.S. § 311(A).

Rule	Violation	Fine Amount
Registration & Permit Requirements		
165:26-1-41	Failure to amend registration within 30 days to reflect changes in tank status	\$500
165:26-1-42	Failure to register tanks within 30 days of bringing the system into service	\$500
165:26-1-42	Operating a tank without a valid permit	\$1,000
165:26-1-47	Failure to amend registration within 30 days to reflect change in ownership	\$500
165:26-1-70	Failure to pay AST permit fees prior to due date	Not > 50% of fee
Notification Requirements		
165:26-1-41	Failure to identify all storage tanks on notification form after third request, including a letter advising tank owner of the penalty	\$1,000
165:26-1-41	Failure to notify PSTD in the required online format and timeframe	\$250
	Second offense	\$500
	Third offense	\$750
165:26-1-42	Failure to notify PSTD prior to AST installation.	\$500
165:26-1-48	Failure to report non-passing tank or line tightness test results.	\$500
165:26-1-57	Failure to provide installation information on notification form after third request, including a letter advising tank owner of the penalty.	\$1,000
165:26-2-210	Failure to notify PSTD prior to AST closure	\$500
165:26-3-77	Failure to report to PSTD within 24 hours of discovering any PSTD regulated substances, conditions or monitoring results that indicate a reportable release may have occurred	\$250
Required Reports		

165:26-1-57	Failure to submit tank closure report within 45 days	\$250
Rule	Violation	Fine Amount
165:26-3-171	Failure to submit required reports pertaining to suspected release investigations and/or corrective action activities in a timely manner	\$250
	Second offense for same case or facility number	\$500
	Third offense for same case or facility number	\$750
General Leak Detection Requirements		
165:26-1-55 165:26-1-58	Failure to maintain records of release or leak detection monitoring	\$250
165:26-1-56	Failure to retain records of calibration, maintenance, and repair of release or leak detection equipment	\$250
165:26-3-19 165:26-3-20	Failure to provide adequate release or leak detection for storage tank system	\$250
	Second Offense	\$500
	Third Offense	\$1,000
165:26-3-20	Failure to monitor tank(s) for releases as required	\$250
165:26-3-20.1	Failure to use approved release or leak monitoring method for tank	\$250
165:26-3-20.1 165:26-3-20.2	Failure to use approved release or leak monitoring method for piping	\$250
Spill & Overfill Prevention		
165:26-1-59	Failure to maintain spill and overfill records	\$250
165:26-2-5.1	Tank owner/operator accepting delivery into an AST that does not have spill or overfill protection	\$1,000
Operation and Maintenance of Corrosion Protection		
165:26-1-58	Failure to provide a Cathodic Protection Design or Suitability Study	\$1,000
165:26-2-40	Tank owner/operator accepting delivery into an AST that does not have a required corrosion protection system	\$1,000
165:26-2-41	Failure to properly operate and maintain corrosion protection system (first offense)	\$150
	Second Offense	\$500
	Third Offense	\$1,000
165:26-2-42	Failure to properly and/or timely test corrosion protection system	\$250
165:26-2-42	Failure to maintain records of cathodic protection system every 60 days	\$250 (per period)

165:26-2-42	Failure to use a licensed cathodic protection tester to inspect corrosion protection system at least once every three years (first offense)	\$500
	Second Offense	\$1,000
Rule	Violation	Fine Amount
165:26-2-42	Failure to test cathodic protection system within 6 months installation or repair	\$250
Release Investigation & Confirmation		
165:26-3-171	Failure to conduct tightness test(s) to investigate suspected leak(s)	\$250
165:26-3-171	Failure to investigate a spill or a spill resulting from overfill over 25 gallons	\$100
165:26-3-171	Failure to clean up a spill or a spill resulting from overfill over 25 gallons	\$500
Temporary Closure		
165:26-2-212	Failure to provide adequate release detection as required in a temporarily closed storage tank system	\$250
165:26-2-212(2)	Failure to properly vent a temporarily closed storage tank system as required	\$250
165:26-2-212(3)	Failure to secure all storage tank-related equipment for temporary closure.	\$250
Permanent Closure		
165:26-2-213	Failure to use a PSTD licensed AST Remover	\$5,000
165:26-2-214	Failure to measure for the presence of a release before a permanent closure	\$500
165:26-2-214(d)	Failure to use a PSTD licensed Environmental Consultant	\$500
Repairs		
165:26-1-56	Failure to maintain repair records for operating life of storage tank	\$250
165:26-2-1.1 165:26-2-191	Failure to use a PSTD licensed AST Installer to install or repair as required	\$5,000
	Second offense or thereafter by owner (per owner, not per facility)	\$1000
165:26-2-8	Failure to perform tightness test on tank system after installation or repair	\$300
Other		
165:15-7-1	Misrepresentation of octane level per location	\$500

	Second Offense within a year	\$1000
	Third Offense – Closure & Hearing	\$5000
165:26-1-31	Failure to follow standard codes for installation	\$500
Rule	Violation	Fine Amount
Administrative Penalty	Any owner or operator of a storage tank who fails to comply with any order issued by the Commission for corrective or enforcement actions may be subject, after notice and hearing, to a fine in an amount as allowed by law.	

[Source: Revoked and reenacted at 21 Ok Reg 2079, eff 7-1-04; Revoked and reenacted at 23 Ok Reg 2297, eff 7-1-06; Revoked and reenacted at 25 Ok Reg 2187, eff 7-11-08; Revoked and reenacted at 35 Ok Reg 1010, eff 10-1-18; Revoked and reenacted at 36 Ok Reg 589, eff 8-1-19; Revoked and reenacted at 37 Ok Reg 1143, eff 10-1-20; Added at 40 Ok Reg 1797, eff 10-1-23; Amended at 41 Ok Reg 1803, eff 10-1-24]

**APPENDIX H. SPACING (SHELL TO SHELL) BETWEEN
ADJACENT TANKS**

Fixed or Horizontal Tanks

	Floating Roof Tanks	Class I or II Liquids	Class IIIA Liquids
Tanks not over 150 ft in diameter	1/6 sum of adjacent tank diameters but not less than 3 ft.	1/6 sum of adjacent tank diameters but not less than 3 ft.	1/6 sum of adjacent tank diameters but not less than 3 ft.
Tanks larger than 150 ft in diameter			
If remote impounding is provided in accordance with 2- 3.4.2	1/6 sum of adjacent tank diameters	1/4 sum of adjacent tank diameters	1/6 sum of adjacent tank diameters
If diking is provided in accordance with 2- 3.4.3	1/4 sum of adjacent tank diameters	1/3 sum of adjacent tank diameters	1/4 sum of adjacent tank diameters

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

APPENDIX I. TOTAL CAPACITY OF VENTING DEVICES

Table Wetted Area versus ft³ (Cubic Feet) Free Air per Hour [14.7 psia and 60°F (101.3 kPa and 15.6°C)].

ft ²	CFH	CFH
20	21,100	
30	31,600	
40	42,100	
50	52,700	
60	63,200	
70	73,700	
80	84,200	
90	94,800	
100		105,000
120		126,000
140		147,000
160		168,000
180		190,000
200		211,000
250		239,000
300		265,000
350		288,000
400		312,000
500		354,000
600		392,000
700		428,000
800		462,000
900		493,000
1000		524,000
1200		557,000
1400		587,000
1600		614,000
1800		639,000
2000		662,000
2400		704,000
2800 & over		742,000

SI units: 10 ft² = 0.93 m²; 36 ft³ = 1.0 m³.1

Interpolate for intermediate values.

[Source: Added at 17 Ok Reg 2875, eff 7-15-00]

APPENDIX J. TABLE ESTABLISHING PERMEABILITY RATES FOR SECONDARY CONTAINMENT

Substance Classification	If groundwater or bedrock is less than 10 feet from grade or AST is within 100 feet of Class II water*	If groundwater or bedrock is greater than 10 feet from grade and AST is not within 100 feet of Class II water
Type A	At least three feet (horizontal thickness) of soil with a minimum permeability of 1×10^{-5} cm/sec	At least three feet (horizontal thickness) of soil with a minimum permeability of 1×10^{-4} cm/sec
Type B	At least three feet (horizontal thickness) of soil with a minimum permeability of 1×10^{-4} cm/sec	At least three feet (horizontal thickness) of soil with a minimum permeability of 1×10^{-3} cm/sec
Type C	At least three feet (horizontal thickness) of soil with a minimum permeability of 1×10^{-3} cm/sec	No minimum permeability standard.

(A) Type A substances include gasoline, diesel, aviation fuel, kerosene, antifreeze, motor oil and motor fuel.

(B) Type B substances include jet fuel, fuel oil types 1 through 4, virgin lube oil, used oils and mixtures or blends of these substances with Type C substances.

(C) Type C substances include fuel oil types 5 and 6 and other regulated Substances.

*Class II (General Use Groundwater): These are groundwaters capable of being used as a drinking water supply with no special treatment or with conventional treatment methods, which have the potential to be used for other beneficial uses and which have a mean concentration of Total Dissolved Solids of less than 3,000 milligrams per liter. [Oklahoma Water Resources Board, Oklahoma's Water Quality Standards, OAC 785:45-7-3(a)(2)]

[Source: Added at 17 Ok Reg 2875, eff 7-15-00; Revoked and reenacted at 21 Ok Reg 2079, eff 7-1-04; Revoked and reenacted at 33 Ok Reg 615, eff 8-25-16]