

ANNUAL RELEASE DETECTION TESTING RECORDKEEPING FORM

OKLAHOMA CORPORATION COMMISSION
 PETROLEUM STORAGE TANK DIVISION
 P.O. Box 171
 Oklahoma City, OK 73101

REQUIRED ANNUALLY

LOCATION OF TANK(S)

Facility Name or Company Site Identifier

Physical Address (PO Box NOT acceptable)

City, State & Zip

County

Inspection Date : ___ / ___ / ___

Facility Number: _____

Component Tested	Name of Tester	Pass/Fail	Needs Action? (Y, N, or N/A)	Action Taken To Correct Issue
Automatic tank gauge and other controllers: test alarm; verify system configuration; test battery backup.				
Probes and sensors: inspect for residual buildup; ensure floats move freely; ensure shaft is not damaged; ensure accessible cables are free of kinks and break; test external alarm operability and communication with controller.				
Automatic line leak detector: test to ensure device can detect 3 gallons per hour at 10 pounds per square inch (or equivalent) within one hour by simulating a leak.				
Vacuum pumps and pressure gauges: ensure proper communication with sensors and controller. (Refer to PEI 900)				
Hand-held electronic sampling equipment associated with groundwater and vapor monitoring: ensure proper operation.				

Other Components Tested:

Notes:

Technician Company : _____ **Technician Signature:** _____

Technician Name: _____

Keep this record for three years.