

OKLAHOMA CORPORATION COMMISSION – PETROLEUM STORAGE TANK DIVISION
P. O. Box 171, Oklahoma City, OK 73101
(405) 521-4683

IMPRESSED CURRENT CATHODIC PROTECTION SYSTEM 60-DAY RECTIFIER INSPECTION

YEAR FACILITY NAME FACILITY ID NUMBER

FACILITY ADDRESS CITY ZIP PHONE

THIS INFORMATION MUST BE PROVIDED BY CATHODIC PROTECTION SPECIALIST WHO INSTALLED OR REPAIRED SYSTEM:

RECOMMENDED RANGE – AMPS _____

RECOMMENDED RANGE – VOLTS _____

NOTE TO OWNER: IF YOUR CP SYSTEM IS NOT WORKING PROPERLY, YOU MUST HAVE A CORROSION EXPERT INVESTIGATE AND FIX THE PROBLEM. A CORROSION EXPERT MUST BE EITHER (1) ACCREDITED/CERTIFIED BY NACE INTERNATIONAL AS A CORROSION SPECIALIST OR CP SPECIALIST, OR (2) A REGISTERED PROFESSIONAL ENGINEER WITH CERTIFICATION OR LICENSING IN CORROSION CONTROL. YOU MUST KEEP A RECORD OF ALL CP INSTALLATION DESIGNS AND REPAIRS FOR AS LONG AS YOU OWN THE TANK(S).

INSPECTION DATA

DAY INSPECTED	AMP READING	VOLT READING (If Equipped)	HOUR METER (If Equipped)	IS SYSTEM RUNNING PROPERLY?	YOUR SIGNATURE

IF THE RECTIFIER AMP OR VOLT READINGS ARE OUTSIDE THE RECOMMENDED OPERATING LEVELS ABOVE, CONTACT A CERTIFIED CATHODIC PROTECTION EXPERT/SPECIALIST TO INVESTIGATE THE PROBLEM.

IMPRESSED CURRENT SYSTEMS MUST MAINTAIN ELECTRIC POWER AT ALL TIMES – DON'T TURN OFF YOUR RECTIFIER

KEEP THIS RECORD ON FILE FOR AT LEAST THREE (3) YEARS