

RETURN TO SERVICE OF TEMPORARILY CLOSED PETROLEUM STORAGE TANKS

OKLAHOMA CORPORATION COMMISSION
 PETROLEUM STORAGE TANK DIVISION
 P.O. Box 171
 Oklahoma City, OK 73101

Facility Number: _____ Total No. of Tanks at Facility: _____ Number of UST's at Facility: _____ Number of AST's at Facility: _____	STATE USE ONLY DATE RECEIVED: A. Date entered into computer: B. Data entry clerk initials:
---	--

GENERAL INFORMATION

Storage tanks containing antifreeze, motor oil, motor fuel, gasoline, kerosene, diesel or aviation fuel are regulated by the Oklahoma Corporation Commission's Petroleum Storage Tank Division. Underground petroleum storage tanks with capacity over 110 gallons must be registered, except for residential and non-commercial agricultural tanks with capacity of less than 1,100 gallons. Aboveground petroleum storage tanks with capacity over 110 gallons must be registered, except for farm and ranch tanks, emergency generator tanks, or tanks at fleet and commercial facilities less than 2,100 gallons individual storage capacity. Fuel cannot be dispensed until a valid permit is issued by PSTD.

I. OWNERSHIP OF TANK (S)	II. LOCATION OF TANK (S)
_____ Owner Name (Corporation, Individual, Public Agency) _____ Mailing Address _____ City & State Zip Code () () Phone Number Mobile Number () Fax Number E-mail Address	_____ Facility Name or Company Site Identifier, as applicable _____ Physical Address (PO Box <u>NOT</u> acceptable) _____ City & State Zip Code _____ () County Facility Phone Number _____ Contact Person & Title

III. TANKS RETURNING TO SERVICE

Tank ID	Tank Serial No.	Capacity (Gals.)	Product Stored	Date scheduled for return to service	Check All That Apply
					<input type="checkbox"/> UST <input type="checkbox"/> AST <input type="checkbox"/> Underground Piping
					<input type="checkbox"/> UST <input type="checkbox"/> AST <input type="checkbox"/> Underground Piping
					<input type="checkbox"/> UST <input type="checkbox"/> AST <input type="checkbox"/> Underground Piping
					<input type="checkbox"/> UST <input type="checkbox"/> AST <input type="checkbox"/> Underground Piping

CATHODIC PROTECTION	If tanks and/or piping are cathodically protected, provide evidence of current CP certification by qualified tester and bimonthly rectifier inspection, if equipped. If bimonthly rectifier inspections are not available, CP system must be recertified prior to reopening. Submit applicable test documentation with this notification.
----------------------------	---

REQUIRED ATTACHMENTS	- Tank Tightness Test (if temporarily closed > 12 months) - Leak Detector Test (if temporarily closed > 12 months) - Line Tightness Test (if temporarily closed > 12 months) - CP Recertification and inspections (if applicable)
-----------------------------	--

IV. CERTIFICATION (Read and sign after completing all sections)

I certify under penalty of law that I have personally examined and am familiar with the information submitted in this and all attached documents, and that I believe that the submitted information is true, accurate and complete.

(Print) Owner or authorized representative	Title
X	
Signature	Date